



12 South Center Street  
Bensenville, IL 60106  
Office 630.350.3404  
Fax 630.350.3438  
[www.bensenville.il.us](http://www.bensenville.il.us)

VILLAGE BOARD

February 26, 2017

**Board of Trustees**

Rosa Caminos  
Frank BeCmane  
Anne Jaworska  
David Magoski  
Martin O'Connell  
Henry Wiesniewski

**Village Clerk**

Rosa Pivato-Trappola

**Village Manager**

Evan F. Summers

**Ms. Dominika Pikul**  
7151 West Belmont Avenue  
Chicago, Illinois 60634

Re: February 24, 2017 FOIA Request

Dear Ms. Pikul:

I am pleased to help you with your February 24, 2017 Freedom of Information Act ("FOIA"). Your request was received by the Village of Bensenville on February 24, 2017. You requested copies of the items indicated below:

*"Property Address: 310 Meyer Rd, Bensenville, IL 60106. Please provide any documents in regards to any open records, unpaid fees, zoning, violations and village's inspection. Also, any records of environmental concerns."*

After a search of Village files, the following information was found responsive to your request:


- 1) Village of Bensenville Certificate of Compliance for Inspection Number 35285. (1 pg.)

These are all the records found responsive to your request.

In regards to storage tanks, please contact the Illinois State Fire Marshall's Office to ensure no records exist.

Please be aware that on February 25, 2014 the Village Board adopted Ordinance No. 16-2014 that requires a Real Estate Transfer Inspection (RETI) be conducted prior to most property sales within Bensenville. For additional information regarding the RETI inspection, please contact the Community & Economic Development Department at 630-766-8200.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,  
  
Corey Williamsen  
Freedom of Information Officer  
Village of Bensenville

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

## **CERTIFICATE OF COMPLIANCE**

**For: 2015 NON-RESIDENTIAL**

## ANNUAL INSPECTION

Inspection Number: 35285

**DATE: May 6, 2015**

**This certifies that:**

**D & L Sales**

**310 Meyer Road,**

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

**Business may continue on the current issued Village License.**

Exit Lights to be lit at all times and Emergency Back-Up lights need to function as designed and illuminate upon testing. If either of these lights do not illuminate upon testing, the battery may need to be changed or the entire unit needs replacing.

All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

LINDSAY LAYCOAX

### **Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS