



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

April 13, 2017

Board of Trustees

Rosa Cammina
Frank DeSimone
Annie Jaworska
David Majeski
Martin O'Connell
Henry Wesseler

Village Clerk
Ilisa Rivers-Freipold

Village Manager
Evan K. Summers

Mr. John S. Goin
P.O. Box 545
Mundelein, Illinois 60060

Re: April 11, 2017 FOIA Request

Dear Mr. Goin:

I am pleased to help you with your April 11, 2017 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on April 11, 2017. You requested copies of the items indicated below:

"Review fire and building permit records for original occupancy permit, past tenant occupancy permits, permits for chemical use or storage, USTs, ASTs, spills or hazmat incidents for 420 Podlin."

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Inspection Number 11858. (2 pgs.)

These are all of the documents that can be discovered responsive to your request.

Please contact the Illinois State Fire Marshall's Office for potential records for USTs, ASTs, spills or hazmat incidents for 420 Podlin

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,


Corey Williamsen
Freedom of Information Officer
Village of Bensenville



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: ANNUAL INSPECTION

CORRECTION NOTICE

| | | | |
|--------------------|-------------------------------|---|-----------------------------------|
| Address: | 420 PODLIN | Unit: | |
| Business name:: | THE FLOLO CORPORATION | Phone: | |
| Business Owner: | FLOLO CORP. | Address: | 420 S PODLIN DR FRANKLIN PARK, IL |
| Inspection Date: | 7/18/13 | Inspector: | TOM KNIGHT |
| <u>Checklist #</u> | <u>Violation</u> | <u>Violation comment</u> | |
| 060B | ILLEGAL LOCKING DEVICE | Remove barricade locking device from rear EXIT door. | |
| 090Z | OTHER | Remove hoist from bar joist. | |
| 160P | ILLEGAL SPRAY BOOTH | Fire detection and protection systems are required for all spray booths. Provide detection and protection systems for spray booth. A permit is required. Contact Inspector Tony Bagnola at Village Hall for assistance. | |
| 165 | FIRE ALARM | A fire alarm is required for this building. Contact Inspector Tony Bagnola at Village Hall for information. | |
| 175H | KEEP PALLETS BELOW 6 FT. HIGH | Do not store idle pallets on racks/shelves. | |
| 180K | VENDING LICENSE - ANNUALLY | Vending license is required for all soda/snack machines. | |

Additional Remarks/Comments:

Reinspection 23287 created on 07/18/2013
by 6523tkni

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: ANNUAL INSPECTION

CORRECTION NOTICE

Address: 420 PODLIN Unit:

Business name: THE FLOLO CORPORATION Phone:

Business Owner: FLOLO CORP. Address: 420 S PODLIN DR FRANKLIN PARK, IL

Inspection Date: 7/18/13 Inspector: TOM KNIGHT

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____