



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

May 18, 2017

President
Frank DeSimone

Board of Trustees
Rosa Campona
Ann Frenz
Agnieszka "Anee" Jaworska
McLane Lomax
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

Ms. Anna Polek
442 Park Street
Bensenville, Illinois 60106

Re: May 18, 2017 FOIA Request

Dear Ms. Polek:

I am pleased to help you with your May 18, 2017 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on May 18, 2017. You requested copies of the items indicated below:


"Any permits and violations issued for 442 Park St, Bensenville, IL in the last 15 years."

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Permits Issued to 442 Park Street. (1 pg.)
- 2) Village of Bensenville Inspection No. 48272. (2 pgs.)

These are all of the documents that can be discovered responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville

Application Reference	Project/Activity	Location	Municipality	App Status	User Status	Application Recv'd	Applicant Role	Contractor	Project/Activity Desc Line 2	Actual End Date	Permit Number
6748	SINGLE FAMILY ACC/ALT/REP	442 SOUTH PARK STREET	BENSENVILLE	ACTIVE	ACTIVE	01/25/2017	OWNER	ELECTRIC WORK		105676	
1904	ROOF, GUTTERS, SIDING SF	442 PARK	BENSENVILLE	COMPLETE	FINALED	07/27/2011	ROOFER	CERNY CONSTRUCTION INC.	RE-ROOF	07/20/2016	101365



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: RETI: TRANSFER INSPECTION

CORRECTION NOTICE

Address:	442 PARK	Unit:	
Business name::	Mutual realty	Phone:	630-595-5725
Business Owner:		Address:	
Inspection Date:	12-28-16	Inspector:	RON HERFF
<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>	
040B	HANDRAIL NEEDED FOR 4 OR MORE STEPS	Handrail going upstairs is very loose	
050E	GFCI ALL EXTERIOR RECEPTACLES	All exterior outlets including the garage must be GFCI style outlets.	
090D	REPAIR HOLES IN WALL / CEILING	There are holes in the walls and ceilings on the main level and second floor.	
120	INTERIOR ELECTRIC	The electric meter is not grounded, The closet lighting in the upstairs are installed incorrectly. ELECTRIC PERMITS WILL BE REQUIRED FOR ELECTRIC WORK.	
120D	REPLACE PAINTED OUTLETS	All painted outlets must be cleaned or replaced.	
120F	INSTALL REQUIRED GFCI OUTLETS	GFCI outlets are required for all counter height outlets.	
120O	FLUORESCENT FIXTURE IN CLOSETS	All closet lighting may no longer use screw in type light bulbs.	
120R	WATER HEATER NEED TO BE BONDED	Water heater must have bonding wire installed.	
120S	WATER METER NEEDS JUMPER WIRE	Could not locate the water meter	
120Z	OTHER	Garage- If a garage door opener is installed it have safety eyes installed.	
130D	SUMP PUMP IN VIOLATION	The sump pump may be in the crawl space. NOTE: an extension cord in the crawl space.	
140C	IMPROPER GAS SUPPLY LINE	Gas lines for dryer and stove must be upgraded to new style.	
150A	IMPROPER DRYER VENT	Dryer vent pipe may not use plastic flex pipe.	
150D	BATHROOM NEEDS EXHAUST FAN	Second floor bathroom.	
160A	SMOKE DETECTORS NEEDED	Smoke detectors are required in every bedroom. An AC powered Smoke detector is required within 15 feet of all sleeping areas. A smoke detector is also required on every level of the home.	
160B	CARBON MONOXIDE NEEDED	CO detectors are required with in 15 feet of all sleeping areas.	

Additional Remarks/Comments:

Re-inspection is required with-in 30 days.

Reinspection 48314 created on 12/28/2016
by 6523rher

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

**VILLAGE OF BENSENVILLE****INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: RETI: TRANSFER INSPECTION

CORRECTION NOTICE

Address: 442 PARK Unit:

Business name:: Mutual realty Phone: 630-595-5725

Business Owner: Address:

Inspection Date: 12-28-16 Inspector: RON HERFF

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____