



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

May 7, 2018

President

Frank DeSimone

Board of Trustees

Rosa Carmona
Ann Franz
Agnieszka "Annie" Jaworska
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk

Nancy Dunn

Village Manager

Evan K. Summers

Ms. Carolina Cartagena

AEI Consultants

carolinacartahena@outlook.com

Re: May 4, 2018 FOIA Request

Dear Ms. Cartagena:

I am pleased to help you with your May 4, 2018 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on May 4 2018. You requested copies of the items indicated below:


"For the property located at 139 and 230 Foster Avenue: Does the property have any outstanding open building code violations? Does the property have any outstanding open fire code violations?"

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 56720. (1 pg.)

These are all of the documents that can be discovered responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 224 FOSTER

Unit:

Business name: ALL METAL, INC.

Phone: 630-250-8090

Business Owner: PHILIP COLLIN

Address: P.O. BOX 850 BENSENVILLE, IL

Inspection Date: 1-3-2018

Inspector: DON TESSLER

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160E	EMERGENCY LIGHTING INOPERABLE	Check all emergency light units, repair/replace any non-working emergency light units.
160G	EM/EXIT LIGHT BURNED OUT	Repair/replace all burned out exit signs
170G	MISSING ESCUTCHEON RINGS	Repair sprinkler heads in lunch room area that are above the ceiling tile and replace missing escutcheon rings.
180F	SPRINKLER SYSTEM - ANNUALLY	Need a current annual test and cert. of the fire sprinkler system.

Additional Remarks/Comments:

Created from inspection 56696 on
01/03/2018 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____