



12 South Center Street  
Bensenville, IL 60106

Office: 630.350.3404  
Fax: 630.350.3438  
[www.bensenville.il.us](http://www.bensenville.il.us)

**VILLAGE BOARD**

June 19, 2018

**President**  
Frank DeSimone

**Board of Trustees**  
Rosa Campona  
Ann Franz  
Agnieszka "Annie" Jaworska  
McLane Lomax  
Nicholas Pancola Jr.  
Armando Perez

**Village Clerk**  
Nancy Quinn

**Village Manager**  
Evan K. Summers

Ms. Randee Newsom  
401 North College Avenue  
Indianapolis, Indiana 46202

Re: June 13, 2018 FOIA Request

Dear Ms. Newsom:

I am pleased to help you with your June 13, 2018 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on June 18, 2018. You requested copies of the items indicated below:

*"KERAMIDA requests that any environmental files associated with the property of 600 Thomas Drive, Bensenville, IL 60106 be made available to us within three weeks of the receipt of this request. Files related to hazardous chemicals, underground storage tanks, dumping, releases, leaks, spills, wastewater disposal and environmental complaints, investigations and citations are of particular request."*

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 56377. (2 pgs.)


These are all of the documents that can be discovered responsive to your request.

Please contact the Bensenville Fire Department regarding potential records of fires at the property.

Please contact the Illinois State Fire Marshal's Office regarding potential records for UST/AST and hazardous materials.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

  
Corey Williamsen  
Freedom of Information Officer  
Village of Bensenville



**VILLAGE OF BENSENVILLE  
INSPECTORIAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address:	600 THOMAS	Unit:	
Business name::	The PRI Group	Phone:	708-273-8072
	COYOTE TRANSPORTATION, INC.		
Business Owner:	COYOTE TRANSPORTATION, INC.	Address:	600 THOMAS DRIVE BENSENVILLE, IL
Inspection Date:	1/15/2018 12:00:00AM	Inspector:	LINDSAY LAYCOAX
<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>	
010Z	OTHER	Designated "FIRE LANE" striping needed in warehouse!	
020E	REMOVE ALL RUBBISH OR GARBAGE	REMINDER: All grounds must be kept clear of all rubbish and garbage. "All exterior property and premises, and the interior of every structure, shall be free from any accumulation of rubbish or garbage"	
060	EXTERIOR DOOR	All exit doors must be free and clear at all times allowing for a safe and orderly exit from the structure.	
120G	NEED ACCESS TO ELECTRIC PANEL	All storage must be maintained in an orderly fashion. Which will allow unobstructed access to electrical panel for building and machines at all times.	
120Z	OTHER	All storage must be maintained in an orderly fashion. Which will allow unobstructed means of fire suppression and fire extinguishment. Maintain adequate aisle for access. No dead end storage allowed.	
160P	FLAMMABLES IMPROPERLY STORED	Gas cans stored inside should be placed inside a flame resistant cabinet. Gas cans in commercial building MUST be made of metal with vents (NO PLASTIC GAS CONTAINERS ALLOWED IN COMMERCIAL BUILDINGS!).	
175	MEANS OF EGRESS & STORAGE	All storage must be maintained in an orderly fashion. Which will allow unobstructed means of egress at all times.	
175F	KEEP STORAGE BELOW 12 FT. HIGH	All storage must be NOT exceed 12 feet high. Exception paper/cardboard not to exceed 20 ft high. Plastic must be no more than 5 ft high.	
175G	KEEP STORAGE 36 IN. FROM HEATING	All storage must be maintained 36 inches in front of and around heating uniting.	
175H	KEEP PALLETS BELOW 6 FT. HIGH	All storage/stacking of pallets must be NOT exceed 6 feet high.	

**Additional Remarks/Comments:**

Created from inspection 55563 on  
12/05/2017 by 6523llay

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**



**VILLAGE OF BENSENVILLE**  
**INSPECTIONAL SERVICES**  
12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 600 THOMAS

Unit:

Business name:: The PRI Group

Phone: 708-273-8072

COYOTE TRANSPORTATION, INC.

Business Owner: COYOTE TRANSPORTATION, INC.

Address: 600 THOMAS DRIVE BENSENVILLE, IL

Inspection Date: 1/15/2018 12:00:00AM

Inspector: LINDSAY LAYCOAX

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: \_\_\_\_\_

Date: \_\_\_\_\_