



112 South Center Street
Bensenville, IL 60106

Office 630.350.3404
Fax 630.350.3408
www.bensenville.il.us

VILLAGE BOARD

August 21, 2018

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Agnieszka "Annie" Jaworska
McLane Lomaix
Nicholas Pancola Jr.
Armando Perez

Village Clerk
Nancy Dunn

Village Manager
Evan K. Summers

Mr. Andrew Kuby
3000 Dundee Road, Suite 410
Northbrook, Illinois 60062

Re: August 15, 2018 FOIA Request

Dear Mr. Kuby:

I am pleased to help you with your August 15, 2018 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on August 15, 2018. You requested copies of the items indicated below:


"Regarding 1001 Foster Ave."

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Walk-Through Inspection dated 6/21/18. (1 pg.)

These are all of the documents that can be discovered responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville

6-21-2018

Walk-through inspection for potential new tenant, 1001 W. Foster Avenue

- 1) Replace painted receptacles in the mezzanine.
- 2) Receptacle cover plates missing in the mezzanine.
- 3) Properly secure the flexible metal conduit in the mezzanine.
- 4) Install blank cover on junction box in mezzanine ceiling (by stairway).
- 5) Provide current inspection reports for the fire alarm, fire sprinkler and backflow device.
- 6) Remove abandoned electrical conduit and wires back to its source (warehouse).
- 7) Repair/replace several EXIT lights and emergency lights (throughout). 90-minute battery back-up required.
- 8) A Commodity v. Density study will be required prior to racking and stacking any plastic commodities. Contact your fire sprinkler contractor for assistance.