



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

February 22, 2019

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Agnieszka "Anne" Jaworska
McLane Lomax
Nicholas Pancola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

Stateline Environmental
P.O. Box 495
Antioch, Illinois 60002

Re: February 21, 2019 FOIA Request

Dear Stateline Environmental:

I am pleased to help you with your February 21, 2019 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on February 21, 2019. You requested copies of the items indicated below:


"Building Department: Any records pertaining to building permits for construction, demolition and / or renovations as well as any violations that may be on file for the property located at 1011 Sesame Street, Bensenville, Illinois 60106."

After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Permits Issued to 1011 Sesame Street Since January 1, 2010. (1 pg.)
- 2) Village of Bensenville Walk-Thru Inspection Dated 5/24/2018 for 1011 Sesame Street. (2 pgs.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville

Location	Municipality	App Status	Application Recv'd	Project/Activity Desc Line 2
1011 EAST SESAME STREET	FRANKLIN PARK	EXPIRED	07/19/2011	RE-ROOF
1011 EAST SESAME STREET	FRANKLIN PARK	EXPIRED	02/03/2012	SIDING
1011 EAST SESAME STREET	FRANKLIN PARK	ACTIVE	11/09/2016	SIGN

5-24-2018

WALK-THRU INSPECTION

1011 E. SESAME STREET

(vacant Weisheit building)

****The highlighted items shall be corrected prior to occupancy****

- The fire alarm requires an annual inspection. Provide current inspection report.
- The fire sprinkler system requires annual inspection. Provide current inspection report.
- The backflow device requires annual inspection. Provide current inspection report.
- Repair/replace EXIT lights throughout the building. 90-minute battery back-up required.
- Repair/replace the emergency lights throughout the building. 90-minute battery back-up required.
- All bathrooms require mechanical ventilation. Repair/replace exhaust fan in office bathroom.
- GFCI receptacles are required over counter tops. Provide a GFCI receptacle in the conference room.
- Provide breaker locks to the circuits that serve the Fire Alarm Control Panel, EXIT lights and emergency lights.
- Properly identify the circuit serving the Fire Alarm Control Panel with **FIRE ALARM** in red
- Secure the slop sink in the warehouse.
- Remove abandoned electric.
- Fire extinguishers require annual testing/inspection. Provide current inspection tags.
- All fire extinguishers shall be mounted to the wall no higher than 5' off the floor in appropriate locations.
- Provide bonding wires to the water meters and water heater.
- Repair/replace all broken, stained and missing ceiling tiles throughout the building.
- Repair/replace the sink cabinet in the breakroom.
- The STORZ Fire Department Connection requires a 30 degree downturn elbow.
- Repair/replace the lintel over the docks, doors 1 and 2.
- A Commodity v. Density study is required prior to establishing a high pile or rack storage array.
- Supply trunk duct in warehouse has an open end. Cap the end of truck line.

-Replace all painted receptacles

-In the warehouse there are heat ducts that are of PVC and drain tile material. Provide documentation these materials are approved by the manufacturer for this application. If not, material must be changed to one that is.

-Remove the bolts sticking out of the floor (trip hazard).

-All unused or abandoned electrical conduit, conductors, cables, fixtures, equipment, etc. shall be removed.

-All electrical panels shall be completely and properly labeled indicating the specific purpose or use of the circuit breakers.

-If forklifts are to be operated in the warehouse, the electrical panel will require protection from damage (ex. bollards).

-The water heater servicing the warehouse washrooms- vent connector piping requires three screws per connection. Vent pipe heading up through roof requires one clearance to the ceiling tile.

-Storm water cannot discharge into the Village sanitary lines. Provide documentation the roof drains and any sumps are compliant with Village Code.

-A licensed electrician will need to provide documentation that the electrical service is properly grounded and bonded. This can be done with the interior demolition permit when all abandoned wiring will be removed.