



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

July 15, 2019

President
Frank DeSmone

Board of Trustees
Rosa Campona
Ann Franz
Marie T. Frey
McLane Lomas
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Dunn

Village Manager
Evan K. Summers

Ms. Sheneetra Scroggins
The Planning and Zoning Resource Company
1300 South Meridian Avenue, Suite 400
Oklahoma City, Oklahoma 73108

Re: July 8, 2019 FOIA Request

Dear Ms. Scroggins:

I am pleased to help you with your July 8, 2019 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on July 15, 2019. You requested copies of the items indicated below:


"Please provide copies of any open/unresolved Zoning, Building and Fire Code Violations (on file), Variances, Conditional and/or Special Use Permits (excluding signage). And Certificate of Occupancy for the property at: 890 Supreme Dr."

After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 38582. (2 pgs.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address:	850 SUPREME	Unit:	
Business name::	Plastic Recovery Technologies	Phone:	847-860-8800
Business Owner:	Kevin Gavin	Address:	
Inspection Date:	9-25-2015	Inspector:	TOM KNIGHT
<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>	
060C	MEANS OF EGRESS BLOCKED	Remove storage/debris from EXIT access (warehouse west EXIT). Maintain clear EXIT access at all times.	
120G	ACCESS TO ELECTRIC PANEL	Remove storage/debris from in front of electrical panels. Maintain 36" clearance to panels at all times.	
150D	BATHROOM EXHAUST FANS	Repair/replace bathroom exhaust fans.	
160C	EXIT LIGHTS	Repair/replace EXIT lights (front, kitchen, warehouse). 90-minute battery back-up required.	
160D	EMERGENCY LIGHTS	Repair/replace EM lights (kitchen, office). 90-minute battery back-up required.	
160P	PALLETS IMPROPERLY STORED	Idle pallets must be stored in stacks no taller than 6' high. Maintain 48" separation to other combustibles.	
160T	PROPERLY SECURE COMPRESSED GAS	LP gas cylinders must be stored in a cage when not in use.	
165O	HORNS OR STROBES NEED REPAIR	Repair/replace fire alarm A/V device (compactor room).	
180J	BUSINESS LICENSE - ANNUALLY	A BUSINESS LICENSE IS REQUIRED. APPLY FOR BUSINESS LICENSE AT VILLAGE HALL.	

Additional Remarks/Comments:

Must have a re-inspection with-in 30 days

Reinspection 38586 created on 09/29/2015
by 6523tkni

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 850 SUPREME Unit:

Business name:: Plastic Recovery Technologies Phone: 847-860-8800

Business Owner: Kevin Gavin Address:

Inspection Date: 9-25-2015 Inspector: TOM KNIGHT

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____