



12 South Center Street
Bensenville, IL 60106
Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

December 10, 2019

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Marie I. Frey
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Lunn

Village Manager
Evan K. Summers

Mr. Peter Decker
2753 West 31st Street
Chicago, Illinois 60608

Re: December 9, 2019 FOIA Request

Dear Mr. Decker:

I am pleased to help you with your December 9, 2019 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on December 9, 2019. You requested copies of the items indicated below:

"Any records regarding building permits, occupancy permits, underground storage tanks, the storage of hazardous waste and/or fire inspection records at 799 Eagle Drive."

After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Business Licenses Issued to 799 Eagle Drive Since January 1, 2008. (1 pg.)
- 2) Village of Bensenville Correction Notice for Inspection No. 69073. (1 pg.)
- 3) Village of Bensenville Correction Notice for Inspection No. 69074. (1 pg.)

These are all the records found responsive to your request.


In regards underground/aboveground storage tanks and hazardous materials; please check with the Illinois Fire Marshal's Office to conduct a search of their files.

Section 7(1)(b) of FOIA provided that "private information" is exempt from disclosure. "Private information" is defined in FOIA as, "unique identifiers, including a person's social security number, driver's license number, employee identification number, biometric identifiers, personal financial information, passwords, or other access codes, medical records, home or personal telephone numbers, and personal email addresses. Private information also includes home address and personal license plates, except as otherwise provided by law or when compiled without possibility of attribution to any person." 5 ILCS 140/2(c-5). Consequently, certain identifiers have been redacted from the records being provided.

Pursuant to Section 9 of the FOIA, 5 ILCS 140/9, I am required to advise you that I, the undersigned Freedom of Information Officer, reviewed and made the foregoing determination to deny a portion of your FOIA Request as indicated. Should you believe that this Response constitutes an improper denial of your request, you may appeal such by filing a request for review within sixty (60) days of the date of this letter with the Public Access Counselor of the Illinois Attorney General's Office, Public Access Bureau, 500 South Second Street, Springfield, Illinois 62706; telephone 1-887-299-FOIA; e-mail: publicaccess@atg.state.il.us. You may also have a right of judicial review of the denial under Section 11 of the FOIA, 5 ILCS 140/11.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,


Corey Williamsen
Freedom of Information Officer
Village of Bensenville

Status	Location	DBA	Start Date	Last License
ACTIVE	799 EAGLE DRIVE	ALL-STAR TOOL & MOLDS, INC.	01/01/2008	11/22/2019
INACTIVE	799 EAGLE DRIVE C	M Z M	01/01/2008	12/01/2011
ACTIVE	799 EAGLE DRIVE	PINNACLE WIRE EDM INC.	04/07/2014	11/22/2019



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 799 Eagle Dr Unit: A & B

Business name:: ALL-STAR TOOL & MOLDS, INC. Phone: [REDACTED]

Property Owner: HERNER HARRER Address: 799 W EAGLE DRIVE BENSENVILLE, IL

Inspection Date: 7-23-19 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
180D	FIRE ALARM SYSTEM - ANNUALLY	Need to have the Fire Alarm annually certified by a licensed contractor and have the report posted in a conspicuous place next to the panel.

Additional Remarks/Comments:

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

email a.s.tool@sbcglobal.net

Copy of this report received by/mailed to: _____

Lindsay Laycoax

7-23-19

Inspector: _____

Date: _____



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 799 Eagle Dr Unit: C

Business name: PINNACLE WIRE EDM INC. Phone: [REDACTED]

Property Owner: PINNACLE WIRE EDM INC. Address: 799 EAGLE DRIVE UNIT C BENSENVILLE, IL

Inspection Date: 7-23-19 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160	LIFE SAFETY REQUIREMENTS	Exit Lights to be lit at all times and Emergency Back-Up lights need to function as designed and illuminate upon testing. All emergency lights need to be tightly secured and light up the floor/steps to show the path of egress.
180D	FIRE ALARM SYSTEM - ANNUALLY	Need to have the Fire Alarm annually certified by a licensed contractor and have the report posted in a conspicuous place next to the panel.

Additional Remarks/Comments:

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

email pinnacle-799@att.net

Copy of this report received by/mailed to:

Lindsay Laycoax

7-23-19

Inspector:

Date: