



# BENSENVILLE

12 South Center Street  
Bensenville, IL 60106

Office: 630.250.3404  
Fax: 630.250.2408  
[www.bensenville.il.us](http://www.bensenville.il.us)

VILLAGE BOARD

June 23, 2020

President  
Linda LeSemanec

Board of Trustees  
Lisa Corrao  
Andi Evans

Maria L. Frey  
Michelle Lomax  
Nicholas Manocchio Jr.  
Anita M. Perez

Village Clerk  
Darcy Johnson

Village Manager  
Ryan K. Summers

Ms. Kayla Spriegel  
135 South LaSalle Street, Suite 3500  
Chicago, Illinois 60104

Re: June 22, 2020 Commercial FOIA Request

Dear Ms. Spriegel:

I am pleased to help you with your June 22, 2020 Commercial Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on June 22, 2020. You requested copies of the items indicated below:

*"I am looking for records for the three buildings located at 729, 755, 765 N. Route 83 dating back to the buildings' original construction to present day. Fire Department: USTs, ASTs, spills, hazardous materials response calls, fires and inspections. Building Department: Historical building permits, certificates of occupancy, and utility connection information."*

After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 48976. (1 pg.)
- 2) Village of Bensenville Correction Notice for Inspection No. 48977. (1 pg.)
- 3) Village of Bensenville Certificate of Compliance for 729 N. Route 83, Units 304, 305, 306. (1 pg.)
- 4) Village of Bensenville Correction Notice for Inspection No. 48988. (1 pg.)
- 5) Village of Bensenville Correction Notice for Inspection No. 48989. (1 pg.)
- 6) Village of Bensenville Certificate of Compliance for 729 N. Route 83, Unit 309. (1 pg.)
- 7) Village of Bensenville Certificate of Compliance for 729 N. Route 83, Unit 310. (1 pg.)
- 8) Village of Bensenville Certificate of Compliance for 729 N. Route 83, Unit 311. (1 pg.)
- 9) Village of Bensenville Certificate of Compliance for 729 N. Route 83, Unit 315. (1 pg.)
- 10) Village of Bensenville Certificate of Compliance for 729 N. Route 83, Unit 315 & 317. (1 pg.)
- 11) Village of Bensenville Correction Notice for Inspection No. 48983. (1 pg.)
- 12) Village of Bensenville Correction Notice for Inspection No. 48984. (1 pg.)
- 13) Village of Bensenville Correction Notice for Inspection No. 48985. (1 pg.)
- 14) Village of Bensenville Correction Notice for Inspection No. 69769. (1 pg.)
- 15) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 201. (1 pg.)
- 16) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 202. (1 pg.)
- 17) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 203. (1 pg.)
- 18) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 209, 2012, 214, 216. (1 pg.)
- 19) Village of Bensenville Correction Notice for Inspection No. 40584. (1 pg.)
- 20) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 215. (1 pg.)
- 21) Village of Bensenville Correction Notice for Inspection No. 51617. (2 pgs.)
- 22) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 219. (1 pg.)
- 23) Village of Bensenville Correction Notice for Inspection No. 12743. (1 pg.)
- 24) Village of Bensenville Certificate of Compliance for 755 N. Route 83, Unit 221. (1 pg.)
- 25) Village of Bensenville Correction Notice for Inspection No. 49497. (1 pg.)
- 26) Village of Bensenville Correction Notice for Inspection No. 49740. (1 pg.)
- 27) Village of Bensenville Correction Notice for Inspection No. 50757. (1 pg.)
- 28) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 101. (1 pg.)
- 29) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 102. (1 pg.)
- 30) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 103. (1 pg.)
- 31) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 104. (1 pg.)
- 32) Village of Bensenville Correction Notice for Inspection No. 37501. (1 pg.)

- 33) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 108. (1 pg.)
- 34) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 109. (1 pg.)
- 35) Village of Bensenville Correction Notice for Inspection No. 37294. (1 pg.)
- 36) Village of Bensenville Correction Notice for Inspection No. 49793. (1 pg.)
- 37) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 112. (1 pg.)
- 38) Village of Bensenville Correction Notice for Inspection No. 49707. (1 pg.)
- 39) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 114. (1 pg.)
- 40) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 115. (1 pg.)
- 41) Village of Bensenville Correction Notice for Inspection No. 52444. (1 pg.)
- 42) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 111. (1 pg.)
- 43) Village of Bensenville Correction Notice for Inspection No. 12715. (1 pg.)
- 44) Village of Bensenville Correction Notice for Inspection No. 12740. (1 pg.)
- 45) Village of Bensenville Certificate of Compliance for 765 N. Route 83, Unit 122. (1 pg.)
- 46) Village of Bensenville Correction Notice for Inspection No. 49740. (1 pg.)
- 47) Village of Bensenville Correction Notice for Inspection No. 49744. (1 pg.)
- 48) Village of Bensenville Permits Issued to 729, 755, 765 N. Route 83 Since January 1, 2010. (1 pg.)

These are all the records found responsive to your request.

In regards underground/aboveground storage tanks and hazardous materials; please check with the Illinois Fire Marshal's Office to conduct a search of their files.


Please be advised that the Bensenville Fire Protection District No. 2 and the Village of Bensenville are their own Taxing Bodies. For additional information regarding fire at the requested properties, please contact Bensenville Fire Protection District No. 2.

Section 7(1)(b) of FOIA provided that "private information" is exempt from disclosure. "Private information" is defined in FOIA as, "unique identifiers, including a person's social security number, driver's license number, employee identification number, biometric identifiers, personal financial information, passwords, or other access codes, medical records, home or personal telephone numbers, and personal email addresses. Private information also includes home address and personal license plates, except as otherwise provided by law or when compiled without possibility of attribution to any person." 5 ILCS 140/2(c-5). Consequently, certain identifiers have been redacted from the records being provided.

Pursuant to Section 9 of the FOIA, 5 ILCS 140/9, I am required to advise you that I, the undersigned Freedom of Information Officer, reviewed and made the foregoing determination to deny a portion of your FOIA Request as indicated. Should you believe that this Response constitutes an improper denial of your request, you may appeal such by filing a request for review within sixty (60) days of the date of this letter with the Public Access Counselor of the Illinois Attorney General's Office, Public Access Bureau, 500 South Second Street, Springfield, Illinois 62706; telephone 1-887-299-FOIA; e-mail: publicaccess@atg.state.il.us. You may also have a right of judicial review of the denial under Section 11 of the FOIA, 5 ILCS 140/11.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

  
Corey Williams  
Freedom of Information Officer  
Village of Bensenville



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 729 IL RT 83 Unit: 301

Business name: EVER-LEADING INT'L INC. Phone:

Business Owner: EVER-LEADING INT'L INC. Address: 729 N IL RT 83 ROA UNIT 301 BENSENVILLE, IL

Inspection Date: 02-21-17 Inspector: LINDSAY LAYCOAX

Checklist #	Violation	Violation comment
090D	REPAIR HOLES IN WALL/CEILING	Replace all missing, cracked, broken and stained ceiling tiles.
175	MEANS OF EGRESS & STORAGE	All storage must be maintained in an orderly fashion. Which will allow unobstructed access to fire alarm panel at all times.
180B	EXTINGUISHERS - ANNUALLY	All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: February 21, 2017



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 729 IL RT 83 Unit: 302

Business name: RAGOLDS USA, INC. Phone:

Business Owner: RAGOLDS USA, INC. Address: 729 ROUTE 83 SUITE 302 BENSENVILLE, IL

Inspection Date: 02-21-17 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160E	EMERGENCY LIGHTING INOPERABLE	Exit Lights to be lit at all times and Emergency Back-Up lights need to function as designed and illuminate upon testing.
160I	INSTALL 10 POUND ABC EXTINGUISHER	All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 30 April 6,2017 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: February 21, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: EGE Trans USA, Inc.**

**DATE: February 21, 2017**

**This certifies that:**

**EGE Trans USA, Inc.**

**729 N. Route 83**

**Unit 304, 305, 306**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSLEVILLE**  
LINDSAY LAYCOAX Lindsay Laycoax

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**



## VILLAGE OF BENSENVILLE

### INSPECTIONAL SERVICES

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

### CORRECTION NOTICE

Address: 729 IL RT 83 Unit: 307

Business name:: VACANT UNIT Phone:

Business Owner: Address:

Inspection Date: 02-07-17 Inspector: LINDSAY LAYCOAX

Checklist # Violation  
005D LAST ANNUAL INSPECTION DATE Violation comment

Annual inspection or NEW BUSINESS inspection must be scheduled before occupying this unit. Contact The Village of Community & Economic Development 630.350.3411.

#### Additional Remarks/Comments:

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 729 IL RT 83 Unit: 308

Business name: VACANT UNIT Phone:

Business Owner: Address:

Inspection Date: 02-07-17 Inspector: LINDSAY LAYCOAX

Checklist # Violation  
005D LAST ANNUAL INSPECTION DATE Violation comment

Annual inspection or NEW BUSINESS inspection must be scheduled before occupying this unit. Contact Community & Economic Development 630.350.3411.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## CERTIFICATE OF COMPLIANCE

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 48979

DATE: February 21, 2017

This certifies that:

F.H.Paschen, SNNielsen

729 RT.83 UNIT 309,

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

\*\* Must have a clear access of at least 36 inches to electrical panel.

\*\*All storage must be maintained in an orderly fashion. Which will allow unobstructed means of egress at all times.

LINDSAY LAYCOAX

Village of Bensenville Inspector

Lindsay Laycoax

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 48979**

**DATE: February 21, 2017**

**This certifies that:**

**F.H.Paschen, SNNielsen**

**729 RT.83 UNIT 310,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**\*\* Must have a clear access of at least 36 inches to electrical panel.**

**\*\*All storage must be maintained in an orderly fashion. Which will allow unobstructed means of egress at all times.**

**LINDSAY LAYCOAX**

**Village of Bensenville Inspector**

**Lindsay Laycoax**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## CERTIFICATE OF COMPLIANCE

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 48981

DATE: February 21, 2017

This certifies that:

A.O. Freight Corp.,

729 N. Route 83

Unit 311

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

LINDSAY LAYCOAX

Lindsay Laycoax

Village of Bensenville Inspector

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 48982**

**DATE: February 21, 2017**

**This certifies that:**

**Matrix, Inc**

**729 RT.83 UNIT 315,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSONVILLE**

LINDSAY LAYCOAX

Village of Bensenville Inspector

Lindsay Laycoax

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413      Fax: 630.350.3449

## **CERTIFICATE OF COMPLIANCE**

For: 2015 NON-RESIDENTIAL

**ANNUAL INSPECTION**

**Inspection Number: 39487**

**DATE: November 10, 2015**

**This certifies that:**

**MATRIX, INC.**

**729 North Route 83 Unit 315 & 317**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed business license inspection.**

**Business may continue on the current issued Village License.**

LINDSAY LAYCOAX

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address:	729 IL RT 83	Unit:	320	
Business name:	KEARFOTT CORPORATION			Phone: 630.422.7217 cell [REDACTED] Matthew DeCraene (Actuation)
Business Owner:	KEARFOTT CORPORATION			Address: 729 ILLINOIS ROUTE 83 UNIT 320 BENSENVILLE, IL
Inspection Date:	02-21-17			Inspector: LINDSAY LAYCOAX
<u>Checklist #</u>	<u>Violation</u>			<u>Violation comment</u>
160E	EMERGENCY LIGHTING INOPERABLE			Emergency Back-Up lights need to function as designed and illuminate upon testing.
160I	INSTALL 10 POUND ABC EXTINGUISHER			All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 30 April 6,2017 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: February 21, 2017



**VILLAGE OF BENSENVILLE**  
**INSPECTORIAL SERVICES**

12 South Center  
 Bensenville, IL 60106  
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 729 IL RT 83 Unit: 321

Business name: BEELINE LOGISTICS, INS. Phone: 630.422.1361 cell [REDACTED]

Business Owner: BEELINE LOGISTICS, INS. Address: 729 N IL RT 83 ROA UNIT 321 BENSENVILLE, IL

Inspection Date: 02-21-16 Inspector: LINDSAY LAYCOAX

Checklist #  
 180B

Violation  
 EXTINGUISHERS - ANNUALLY

Violation comment

All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE", FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycox Date: February 21, 2017



## VILLAGE OF BENSENVILLE INSPECTORIAL SERVICES

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

### CORRECTION NOTICE

Address: 729 IL RT 83 Unit: 323

Business name: FORBEL ALARMS, INC. Phone: 847-943-9501

Business Owner: FORBEL ALARMS, INC. Address: 729 ILLINOIS ROUTE 83 UNIT 323 BENSENVILLE, IL

Inspection Date: 02-07-17 Inspector: LINDSAY LAYCOAX

Checklist #

Violation

Violation comment

160D	NEED EMERGENCY LIGHT W/ 2HR BU
160E	EMERGENCY LIGHTING INOPERABLE
160K	EXTINGUISHERS MOUNTED WRONG
180B	EXTINGUISHERS - ANNUALLY

The Village requires Emergency back-up lights with a 2 hr. battery back-up.  
Exit Lights to be lit at all times.  
Fire extinguisher must be mounted in place for easy access no more than 48 inches from floor to top of extinguisher.  
10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycox Date: 2/7/2017



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 729 IL ROUTE 83 Unit: 324

Business name: FUMA VAPOR INC Phone: [REDACTED]

Business Owner: FUMA VAPOR INC Address: 729 N RT 83 UNIT 324 BENSENVILLE, IL

Inspection Date: 08/19/2019 Inspector: DON TESSLER

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
165A	NEED TO INSTALL FIRE ALARM	This building requires a full fire alarm system per Village of Bensenville codes, a permit require for this work. Contact inspector Tom Knight 630-341-4541 for assistance.

190L KEY BOX NEEDED

**Additional Remarks/Comments:**

Created from inspection 68850 on 08/19/2019 by 6523dtes

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3414.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 12734**

**DATE: March 7, 2017**

**This certifies that:**

**BISON INTERNATIONAL, INC.**

**755 RT.83 UNIT 201,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**\*\* All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.**

**BENNSVILLE**  
LINDSAY LAYCOAX LINDSAY LAYCOAX  
Village of Bensenville Inspector Lindsay Laycoax Village of Bensenville Inspector's Signature

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## CERTIFICATE OF COMPLIANCE

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 12736

DATE: March 7, 2017

This certifies that:

**AIR-SEA FORWARDERS, INC.**

755 RT.83 UNIT 202,

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

\*\* All openings in electric panel need to be filled with blanks.

**BENSONVILLE**  
LINDSAY LAYCOAX *Lindsay Laycoax*

Village of Bensenville Inspector

Village of Bensenville Inspector's Signature

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 12763**

**DATE: March 2, 2017**

**This certifies that:**

**WEST forwarding services.**

**755 RT.83 UNIT 203,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**LINDSAY LAYCOAX**

**Village of Bensenville Inspector**

**Lindsay Laycoax**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**

**Village of Bensenville**  
**Department of Community and Economic Development**  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413      Fax: 630.350.3449

2017

## **CERTIFICATE OF COMPLIANCE**

## **NON-RESIDENTIAL**

## ANNUAL INSPECTION

Inspection Number: 12735

**DATE: March 7, 2017**

**This certifies that:**

## **Chicago Church OF CHRIST.**

755 RT.83 UNIT 209/212/214/216,

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**\*\* All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.**

**\*\* Emergency Back-Up lights need to function as designed and illuminate upon testing.**

**\*\* All circuit in electrical panel must be clearly identified.**

LINDSAY LAYCOAX

Lindsay Laycoax

## **Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 755 IL RT 83 Unit: 213

Business name: D.B. GROUP AMERICA, LTD. Phone: 718-553-2225

Business Owner: D.B. GROUP AMERICA, LTD. Address: 755 N ROUTE 83 UNIT 213 BENSENVILLE, IL

Inspection Date: 03-2-17 Inspector: LINDSAY LAYCOAX

Checklist # Violation  
180B EXTINGUISHERS - ANNUALLY

Violation comment

All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

Re-inspection is required after 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 2, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 49502**

**DATE: March 14, 2017**

**This certifies that:**

**ALYNEVYCH, INC.**

**755 RT.83 UNIT 215,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issue**

**Village License.**

**LINDSAY LAYCOAX**

**RENSENVILLE**

*Lindsay Laycoax*

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**DEPARTMENT OF  
COMMUNITY & ECONOMIC  
DEVELOPMENT**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address:	755 IL RT 83	Unit:	217
Business name:	SA EXPRESS, INC.	Phone:	773-895-7548 saexpress@gmail.com
Business Owner:	Oleksandr Halka, 773.828.4631	Address:	755 NORTH IL RT 83 ROAD UNIT 217 BENSENVILLE, IL 1700 W. Higgins Rd. Des Plaines, IL 60018
Inspection Date:	June 1, 2017	Inspector:	LINDSAY LAYCOAX
<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>	
160C	NEED EXIT LIGHT W/ 2HR BATTERY	Village requires all Exit lights and Emergency back-up lights with a 2 hr. battery back-up and lights need to function as designed and illuminate upon testing..	
160D	NEED EMERGENCY LIGHT W/ 2HR BU	Emergency back-up lights with a 2 hr. battery back-up and lights need to function as designed and illuminate upon testing. All emergency lights need to light up the floor/steps to show the path of egress.	
160I	INSTALL 10 POUND ABC EXTINGUISHER	All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.	

**Additional Remarks/Comments:**

Reinspection 51713 created on 06/01/2017  
by 6523llay

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 30 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 755 IL RT 83

Unit: 217

Business name: SA EXPRESS, INC.

Phone: 773-895-7548 saexpress@gmail.com

Business Owner: Oleksandr Halka, 773.828.4631

Address: 755 NORTH IL RT 83 ROAD UNIT 217 BENSENVILLE, IL

Inspection Date: June 1, 2017

1700 W. Higgins Rd. Des Plaines, IL 60018

Inspector: LINDSAY LAYCOAX

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector:

Lindsay Laycoax

Date:

June 1, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413      Fax: 630.350.3449

## **CERTIFICATE OF COMPLIANCE**

## For: NON-RESIDENTIAL INSPECTION

Inspection Number: 56466

DATE: 01/10/2018

**APPLICATION NUMBER:**

This certifies that the work completed under the Village of Bensenville

## RFK BUSINESS SOLUTIONS, INC.

755 NORTH IL RT 83 ROAD 219,  
Bensenville, IL 60106

**Has been performed satisfactorily and work may continue on the permit issued for:**

**With the exception of the conditions listed below:**

**NONE**

**DON TESSLER**

## **Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS.



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 755 IL RT 83 Unit: 220

Business name: INDUSTRIAL BUSINESS SERVICES LLC. Phone: 630.766.1400

Business Owner: INDUSTRIAL BUSINESS SERVICES LLC Address: 755 N IL RT 83 ROA UNIT 220 BENSENVILLE, IL

Inspection Date: 09-29-16 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
180B	EXTINGUISHERS - ANNUALLY	All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Last test 2015

**Additional Remarks/Comments:**

Re-inspection is required with-in 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 2, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

## **CERTIFICATE OF COMPLIANCE**

For: 2015 NON-RESIDENTIAL

### **ANNUAL INSPECTION**

**Inspection Number: 37590**

**DATE: August 18, 2015**

**This certifies that:**

**VACANT**

**755 North Route 83<sup>rd</sup> Suite 221,**

**Bensenville, IL 60106**

**Has NOT been inspected and has NOT satisfactorily passed inspection.**

**Business may NOT be started until a current Village License is issued and a complete inspection  
has been satisfactorily completed.**

**LINDSAY LAYCOAX**

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**DEPARTMENT OF COMMUNITY & ECONOMIC  
DEVELOPMENT**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 755 IL RT 83 Unit: 222

Business name: PLOTE CONSTRUCTION, INC. Phone: 847-695-9300

Business Owner: PLOTE CONSTRUCTION, INC. Address: 755 IL ROUTE 83 UNIT 222 BENSENVILLE, IL

Inspection Date: 03-2-17 Inspector: LINDSAY LAYCOAX

Checklist #	Violation	Violation comment
120N	NEED BLANKS IN PANEL	All openings in electric panel need to be filled with blanks.
160E	EMERGENCY LIGHTING INOPERABLE	Emergency Back-Up lights need to function as designed and illuminate upon testing.
160G	EM/EXIT LIGHT BURNED OUT	Exit Lights to be lit at all times and need to function as designed and illuminate upon testing.
160I	INSTALL 10 POUND ABC EXTINGUISHER	All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

Re-inspection is required within 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycox Date: March 2, 2017



**VILLAGE OF BENSENVILLE**  
**INSPECTIONAL SERVICES**

12 South Center  
 Bensenville, IL 60106  
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83 Unit: 123

Business name: OFAH, INC DBA WHITE CITY LOGISTICS Phone: 872-888-1800

[www.whitecitylogistics.com](http://www.whitecitylogistics.com)

Business Owner: OFAH, INC  
 Nash Zivkovic (Pres.) 773.808.1350 Address: 765 IL ROUTE 83 UNIT 123 BENSENVILLE, IL

Inspection Date: 03-14-17 Inspector: LINDSAY LAYCOAX

Checklist #

Violation

Violation comment

160E EMERGENCY LIGHTING INOPERABLE

Emergency Back-Up lights need to function as designed and illuminate upon testing.

160M EXTINGUISHERS INACCESSIBLE

All fire extinguishers must be a minimum of 10# ABC rated and tested every year with a dated tag showing test month and year. Fire extinguisher must be mounted in a easily accessible area no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

Re-inspection will be conducted after 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC - 30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax

Date: March 14, 2017



## VILLAGE OF BENSENVILLE

### INSPECTIONAL SERVICES

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

### CORRECTION NOTICE

Address: 755 IL RT 83 Unit: 223

Business name: Cassey Kobez General Contractor Phone: [REDACTED]

Business Owner: Address:

Inspection Date: 4/25/2017 12:00:00AM Inspector: LINDSAY LAYCOAX

Checklist #  
005

Violation  
VILLAGE REGULATIONS

Violation comment

Permit required for all remodeling. Stop work order imposed  
4/25/2017 @ 11 a.m.

#### Additional Remarks/Comments:

Reinspection 50759 created on 04/25/2017  
by 6523lly

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 7 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: April 25, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## CERTIFICATE OF COMPLIANCE

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 37515

DATE: March 7, 2017

This certifies that:

STAFFING NETWORK.

765 RT.83 UNIT 101

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

\*\* The Village requires all Exit lights and Emergency back-up lights with a 2 hr. battery back-up.

**BENSenville**  
LINDSAY LAYCOAX Lindsay Laycoax

Village of Bensenville Inspector & Village of Bensenville Inspector's Signature

RECEIVED DATE 3/7/2017

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 12720**

**DATE: March 7, 2017**

**This certifies that:**

**PRIME LINE TRANSPORTATION, INC.**

**765 RT.83 UNIT 102**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**\*\* All storage must be maintained in an orderly fashion. Which will allow unobstructed access to electrical panel at all times.**

**LINDSAY LAYCOAX**

**Village of Bensenville Inspector**

**Lindsay Laycoax**

**Village of Bensenville Inspector's Signature**

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 49624**

**DATE: March 7, 2017**

**This certifies that:**

**GLOVAN TRANSPORTATION, INC**

**765 RT.83 UNIT 103**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSENVILLE**

LINDSAY LAYCOAX LLNITY & E Lindsay Laycoax

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## **CERTIFICATE OF COMPLIANCE**

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 12719

DATE: March 7, 2017

This certifies that:

CLASQUIN (USA), INC.

765 RT.83 UNIT 104

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

BENSENVILLE  
LINDSAY LAYCOAX CITY & E *Lindsay Laycoax*  
Village of Bensenville Inspector *✓ E I O P* Village of Bensenville Inspector's Signature

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83 Unit: 105

Business name: DUNNET BAY CONSTRUCTION (dba-CIVILTECH) Phone: 630.773.3900 [www.civiltechinc.com](http://www.civiltechinc.com)

Business Owner: DUNNET BAY CONSTRUCTION Address: 765 N ROUTE 83 BENSENVILLE, IL

Inspection Date: 03-13-17 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160K	EXTINGUISHERS MOUNTED WRONG	All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.
180B	EXTINGUISHERS - ANNUALLY	10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

**Additional Remarks/Comments:**

Re-inspection is required with-in 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 13, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 12721**

**DATE: March 16, 2017**

**This certifies that:**

**RHDC INTERNATIONAL, INC.**

**765 RT.83 UNIT 108,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSENVILLE**

**COMMUNITY & ECONOMIC**

LINDSAY LAYCOAX

Lindsay Laycoax

**DEVELOPMENT**

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 12737**

**DATE: March 16, 2017**

**This certifies that:**

**FATTON LOGISTICS, INC.**

**765 RT.83 UNIT 109,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSENVILLE**

**DEPARTMENT OF COMMUNITY & ECONOMIC DEVELOPMENT**

**LINDSAY LAYCOAX**

**Village of Bensenville Inspector**

**Lindsay Laycoax**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83 Unit: 110

Business name: QUICK FREIGHT LOGISTICS, INC. Phone: 630-475-8125

Business Owner: QUICK FREIGHT LOGISTICS, INC. Address: 765 N IL ROUTE 83 110 BENSENVILLE, IL

Inspection Date: 03-13-17 Inspector: L.Laycoax

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
180B	EXTINGUISHERS - ANNUALLY	10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

**Additional Remarks/Comments:**

Re-inspection is required with-in 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**


You are hereby notified to remedy the conditions as stated above within days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 13, 2017



**VILLAGE OF BENSENVILLE**  
**INSPECTIONAL SERVICES**

12 South Center  
 Bensenville, IL 60106  
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83

Unit: 111

Business name: USA TRANSPORT GROUP

Phone: 888.261.6335 Usatransportgroup.com

Business Owner: Rares Bagiu 773.822.7515

Address:

Inspection Date: 03-16-17

Inspector: LINDSAY LAYCOAX

Checklist # Violation  
 005 VILLAGE REGULATIONS

Violation comment

Conducting business without a current Village of Bensenville Business License. BUSINESS LICENSE MUST BE CURRENT AND BE DISPLAYED IN A PROMINET LOCATION \* MUST COMPLY WITHIN 7 DAYS.\*

10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

180B EXTINGUISHERS - ANNUALLY

**Additional Remarks/Comments:**

Re-inspection is required with-in 30 days.

Business Lic Application must be verified within 7 days from the date on this form.

Reinspection 49794 created on 03/16/2017

by 6523llay

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within 7/30 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 16, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 49897**

**DATE: March 21, 2017**

**This certifies that:**

**M&S Transport, INC.**

**765 IL Route 83 Unit 112,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**RENSENVILLE**  
LINDSAY LAYCOAX Lindsay Laycoax

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**



**VILLAGE OF BENSENVILLE**  
**INSPECTIONAL SERVICES**

12 South Center  
 Bensenville, IL 60106  
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83

Unit: 113

Phone: 847.258.4825 x101 [www.ast-trck.com](http://www.ast-trck.com)

Business name: AST Express

Address:

Business Owner: Arthur Soltys (President)

Inspector: ~~LINDSAY LAYCOAX~~

Inspection Date: 03-13-17

Inspector: ~~LINDSAY LAYCOAX~~

Checklist #

180B

Violation

EXTINGUISHERS - ANNUALLY

Violation comment

10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

**Additional Remarks/Comments:**

Re-inspection is required with-in 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC-30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax

Date: March 13, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 12713**

**DATE: March 13, 2017**

**This certifies that:**

**KJW-CHB LLC**

**765 RT.83 UNIT 114,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSENVILLE**

LINDSAY LAYCOAX

UNITY & E

Lindsay Laycoax

**Village of Bensenville Inspector**

**Village of Bensenville Inspector's Signature**

**KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS**

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## CERTIFICATE OF COMPLIANCE

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 49724

DATE: March 13, 2017

This certifies that:

**NK AMERICA INC.**

765 RT.83 UNIT 115,

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

**BENSENVILLE**

LINDSAY LAYCOAX

Village of Bensenville Inspector

Lindsay Laycoax

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS



**VILLAGE OF BENSENVILLE**  
**INSPECTIONAL SERVICES**

12 South Center  
 Bensenville, IL 60106  
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83 Unit: 116

Business name: LSA INTERNATIONAL INC. Phone: 630-594-4123

Business Owner: LSA INTERNATIONAL INC. Address: 765 N ROUTE 83 SUITE 116 BENSENVILLE, IL

Inspection Date: July 7, 2017 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160E	EMERGENCY LIGHTING INOPERABLE	Exit Lights to be lit at all times and Emergency Back-Up lights need to function as designed and illuminate upon testing.
180B	EXTINGUISHERS - ANNUALLY	10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

**Additional Remarks/Comments:**

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: July 7, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2017**

**CERTIFICATE OF COMPLIANCE**

**NON-RESIDENTIAL**

**ANNUAL INSPECTION**

**Inspection Number: 49751**

**DATE: March 28, 2017**

**This certifies that:**

**USA TRANSPORT GROUP**

**765 RT.83 UNIT 111,**

**Bensenville, IL 60106**

**Has been inspected and satisfactorily passed inspection.**

**Business may continue on the current issued Village License.**

**BENSENVILLE**

LINDSAY LAYCOAX

Village of Bensenville Inspector

Lindsay Laycoax

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS



## VILLAGE OF BENSENVILLE

### INSPECTIONAL SERVICES

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

### CORRECTION NOTICE

Address: 765 N ROUTE 83 Unit: 120

Business name: ORMSBY INTERNATIONAL C H B, INC. Phone: [REDACTED]

Business Owner: RICHARD W. ORMSBY Address: 1684 BRITTANY LN HOFFMAN ESTATES, IL

Inspection Date: 03-13-17 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160E	EMERGENCY LIGHTING INOPERABLE	Emergency Back-Up lights need to function as designed and illuminate upon testing.

#### Additional Remarks/Comments:

Re-inspection is required within 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC-30 days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 13, 2017



**VILLAGE OF BENSENVILLE  
INSPECTIONAL SERVICES**

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 ROUTE 83 Unit: 121

Business name: MAIRON INTERNATIONAL, INC. Phone: [REDACTED] 630.616.8572

Business Owner: GEORGE W. MARSTON Address: JUDSON ST. BENSENVILLE, IL

Inspection Date: 03-13-17 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>
160E	EMERGENCY LIGHTING INOPERABLE
180B	EXTINGUISHERS - ANNUALLY

<u>Violation comment</u>
Emergency Back-Up lights need to function as designed and illuminate upon testing.
10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

**Additional Remarks/Comments:**

Re-inspection is required with-in 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC - 30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 13, 2017

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

2017

## CERTIFICATE OF COMPLIANCE

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 11932

DATE: March 14, 2017

This certifies that:

**DELTA EXPRESS.**

765 RT.83 UNIT 122,

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

**BENSENVILLE**

LINDSAY LAYCOAX

LINDSAY & E Lindsay Laycoax

Village of Bensenville Inspector



Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS



**VILLAGE OF BENSENVILLE**  
**INSPECTIONAL SERVICES**

12 South Center  
 Bensenville, IL 60106  
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

**CORRECTION NOTICE**

Address: 765 IL RT 83 Unit: 123

Business name: OFAH, INC DBA WHITE CITY LOGISTICS Phone: 872-888-1800

[www.whitecitylogistics.com](http://www.whitecitylogistics.com)

Business Owner: OFAH, INC  
 Nash Zivkovic (Pres.) 773.808.1350

Address: 765 IL ROUTE 83 UNIT 123 BENSENVILLE, IL

Inspection Date: 03-14-17 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160E	EMERGENCY LIGHTING INOPERABLE	Emergency Back-Up lights need to function as designed and illuminate upon testing.
160M	EXTINGUISHERS INACCESSIBLE	All fire extinguishers must be a minimum of 10# ABC rated and tested every year with a dated tag showing test month and year. Fire extinguisher must be mounted in a easily accessible area no more than 48 inches from floor to top of extinguisher.

**Additional Remarks/Comments:**

Re-inspection will be conducted after 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC - 30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 14, 2017



## VILLAGE OF BENSENVILLE INSPECTIONAL SERVICES

12 South Center  
Bensenville, IL 60106  
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

### CORRECTION NOTICE

Address: 765 IL RT 83 Unit: 124

Business name: UNITED TRANS GROUP, INC. Phone: 847-869-1922

Business Owner: UNITED TRANS GROUP, INC.  
Hristina Taseva 630.913.1458

Address: 765 N ROUTE 83 UNIT 124 BENSENVILLE, IL  
kris@unitedtransgroup.com

Inspection Date: 03-14-17 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
160G	EM/EXIT LIGHT BURNED OUT	Village requires all Exit lights with a 2 hr. battery back-up and lights must function as designed and illuminate upon testing..
160K	EXTINGUISHERS MOUNTED WRONG	All fire extinguishers must be a minimum of 10# ABC rated and tested every year with a dated tag showing test month and year. Fire extinguisher must be mounted in a easily accessible area no more than 48 inches from floor to top of extinguisher.

#### Additional Remarks/Comments:

Re-inspection will be conducted after 30 days.

**THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.**

You are hereby notified to remedy the conditions as stated above within AWC - 30 days from the date of this order.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.

**DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.**

Copy of this report received by/mailed to: \_\_\_\_\_

Inspector: Lindsay Laycoax Date: March 14, 2017

<b>Location</b>	<b>Municipality</b>	<b>User Status</b>	<b>Application Rec'd</b>	<b>Project/Activity Desc Line 2</b>
729 NORTH IL ROUTE 83	BENSENVILLE	FINALED	06/21/2016	R/R ASPHALT CURB
729 NORTH IL ROUTE 83	BENSENVILLE	FINALED	05/26/2017	PAVING
729 NORTH IL ROUTE 83	BENSENVILLE	FINALED	06/11/2018	PAVEMENT
729 NORTH IL ROUTE 83 302	BENSENVILLE	CLOSED BY INSPECTOR	12/30/2011	LOW VOLT BURGLAR ALARM
729 NORTH IL ROUTE 83 315	BENSENVILLE	CLOSED BY INSPECTOR	12/30/2013	UPGRADE SECURITY ALARM
755 NORTH IL ROUTE 83	BENSENVILLE	FINALED	04/20/2017	OFFICE REMODEL
755 ROUTE 83	BENSENVILLE	CLOSED BY INSPECTOR	04/24/2012	REAL ESTATE SIGN
765 NORTH IL ROUTE 83	BENSENVILLE	ACTIVE	09/13/2019	BURGLAR ALARM