



12 South Center Street  
Bensenville, IL 60106

Office: 630.350.3404  
Fax: 630.350.3438  
[www.bensenville.il.us](http://www.bensenville.il.us)

**VILLAGE BOARD**

December 15, 2020

**President**  
Frank DeSimone

**Board of Trustees**  
Rosa Camarena  
Ann Franz  
Marie T. Frey  
McLane Lomax  
Nicholas Panicola Jr.  
Armando Perez

**Village Clerk**  
Nancy Quinn

**Village Manager**  
Evan K. Summers

**Mr. Ethan Burnett**  
7237 West Devon Avenue  
Chicago, Illinois 60631

**Re:** December 14, 2020 FOIA Request

Dear Mr. Burnett:

I am pleased to help you with your December 14, 2020 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on December 14, 2020. You requested copies of the items indicated below:

*"Please see the attached request regarding the facility located at 789 Golf Lane."*

After a search of Village files, the following information was found responsive to your request:


- 1) Village of Bensenville Certificate of Compliance for Inspection No. 33399. (1 pg.)
- 2) Village of Bensenville Permits Issued to 789 Golf Lane Since January 1, 2010. (1 pg.)

These are all the records found responsive to your request.

In regards underground/aboveground storage tanks and hazardous materials; please check with the Illinois Fire Marshal's Office to conduct a search of their files.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

  
Corey Williamsen  
Freedom of Information Officer  
Village of Bensenville

Village of Bensenville  
Department of Community and Economic Development  
12 S. Center Street, Bensenville, IL 60106  
Phone: 630.350.3413 Fax: 630.350.3449

**2019**

**CERTIFICATE OF COMPLIANCE**

NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 33399

DATE: November 12, 2019

This certifies that:

**GAIM ENGINEERING, INC.**  
789/791 GOLF LANE  
BENSENVILLE IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

LINDSAY LAYCOAX

Lindsay Laycoax

Village of Bensenville Inspector

Village of Bensenville Inspector's Signature

Idle pallets shall be stored in stacks no higher than 6' tall. Maintain 48" clearance to other commodities.

10# ABC rated and tested every year with a correct corresponding tag showing test month and year.

"Windows, and Doors including Overhead Doors. Every exterior window, door and frame shall be kept in sound condition, good repair and weather tight."

Rolling Fire Door Required Annual Testing/Inspection. Provide current inspection sticker and mount on door jamb.

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS

<b>Location</b>	<b>Municipality</b>	<b>App Status</b>	<b>Application Recv'd</b>	<b>Project/Activity Desc Line 2</b>
789 WEST GOLF LANE	BENSENVILLE	COMPLETE	09/08/2015	R/R CONCRETE LOADING DOCK DRIVEWAY
789 WEST GOLF LANE	BENSENVILLE	ACTIVE	09/22/2020	R/R PAVEMENT