



12 South Center Street
Bensenville, IL 60106

Office 630.350.3404
Fax 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

February 19, 2021

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz

Mane T. Frey
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

Mr. David Tran
77 West Jackson Blvd.
Chicago, Illinois 60604

Re: February 18, 2021 FOIA Request

Dear Mr. Tran:

I am pleased to help you with your February 18, 2021 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on February 18, 2021. You requested copies of the items indicated below:

"Purline Treatment Systems 1241 North Ellis Street, Bensenville, IL 60106. Please contact via phone."


After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 31945. (1 pg.)
- 2) Village of Bensenville Certificate of Compliance for Inspection No. 31945. (1 pg.)
- 3) Village of Bensenville Correction Notice for Inspection No. 73740. (1 pg.)
- 4) Village of Bensenville Photos of Outdoor Storage at 1241 North Ellis Street. (7 pgs.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,


Corey Williamsen
Freedom of Information Officer
Village of Bensenville



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: BUSINESS LICENSE INSPECTION

CORRECTION NOTICE

Address: 1241 ELLIS Unit:

Business name:: PURELINE TREATMENT SYSTEMS, LLC Phone: 847-963-8465

Business Owner: PURELINE TREATMENT SYSTEMS, LLC Address: 1241 ELLIS STREET BENSENVILLE, IL

Inspection Date: 10/16/14 Inspector: TOM KNIGHT

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
020H	OUTSIDE STORAGE	Outdoor storage is limited to the rear of the building and 25% of the property area by right. Following move-in transition period, please limit outdoor storage as discussed.
130	INTERIOR PLUMBING	Expansion tank required at water heater.
160M	EXTINGUISHERS INACCESSIBLE	Remove storage/debris from around fire extinguishers. maintain clear access at all times.

Additional Remarks/Comments:

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.


DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____

Village of Bensenville
Department of Community and Economic Development
12 S. Center Street, Bensenville, IL 60106
Phone: 630.350.3413 Fax: 630.350.3449

CERTIFICATE OF COMPLIANCE



TOM KNIGHT

Village of Bensenville Inspector

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS













