



12 South Center Street  
Bensenville, IL 60106

Office: 630.350.3404  
Fax: 630.350.3438  
[www.bensenville.il.us](http://www.bensenville.il.us)

**VILLAGE BOARD**

March 10, 2021

**President**  
Frank DeSimone

**Board of Trustees**  
Rosa Campona  
Ann Frazz  
Marie T. Frey  
McLane Lomax  
Nicholas Panciroli Jr.  
Armando Perez

**Village Clerk**  
Nancy Quinn

**Village Manager**  
Evan K. Summers

**Mr. Thomas C. Hunt**  
1035 South York Road  
Bensenville, Illinois 60106

**Re:** March 3, 2021 FOIA Request

Dear Mr. Hunt:

I am pleased to help you with your March 3, 2021 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on March 3, 2021. You requested copies of the items indicated below:

*"See attached rider for request."*


After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Cartograph No. 2718. (2 pgs.)
- 2) State of Illinois Department of Transportation Diary of Resident Engineer No. 61D60. (2 pgs.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

  
Corey Williamsen  
Freedom of Information Officer  
Village of Bensenville

## RIDER


Documents that are being requested pursuant to the Freedom of Information Act Request Form dated March 3<sup>rd</sup>, 2021 include: any and all correspondences (emails) regarding complaints to the Village of Bensenville concerning the deficient sewer caps on Church Road in Bensenville. Requestor is also seeking the date(s) that the remedial work was started and completed on the sewer caps on Church Road.

# Request Detail

Request ID	Issue	Location	Status	Owner	Department
------------	-------	----------	--------	-------	------------

2718	PW - Engineering	247 S CHURCH RD	Closed	Engineering
------	------------------	-----------------	--------	-------------

**Description** Several seniors were complaining that the new sewer covers were not flush with the pavement along the new portion of Church Road. Please let me know the resolution and I can relay the message.



## Requester Information

Name	Phone	Observed	Notes
------	-------	----------	-------

Evan Summers	6303503420	2/6/2018
--------------	------------	----------

## Task Information

Task ID	Activity	Asset	Priority	Status	Total Cost
---------	----------	-------	----------	--------	------------



## Request Detail

Request ID	Description
2718	Several seniors were complaining that the new sewer covers were not flush with the pavement along the new portion of Church Road. Please let me know the resolution and I can relay the message.

Request Issue Requests Issue

Status Closed

Entered By	Entry Date	Notes Log
mpatel	6/22/2018	We are pursuing steel adjustment rings to fix the manhole elevation issue. The submittal from the contractor is under review. Once approved, the lead time on the steel rings is 6-8 weeks from the time of order due to it being a special order.
mpatel	2/7/2018	This item will be addressed during the punch list items in the Spring of 2018. The contractor has been made aware of the situation. While we can't dictate the means and methods of the contractor, the situation will be addressed in the Spring of 2018. Couple of options discussed with contractor are heating up the asphalt around the structure and roll it flush with the frame or remove and replace a 4x4 square of pavement and replace it with concrete.
mpatel	10/8/2018	The manholes have been raised to the proper elevation in September 2018

Activity	Department	Entered By	Notes	Status

<b>Contract:</b>	61D60	<b>State of Illinois</b>	<b>Resident:</b>	Mehul Patel
<b>County:</b>	DUPAGE	<b>Department of Transportation</b>	<b>Supervisor:</b>	Jeffrey Mysliwiec
<b>Section:</b>	16-00094-00-FP	<b>ICORS System</b>	<b>Field Office Phone:</b>	(630)660-6180
<b>Route:</b>	FAU RTE 2667 (CHURCH ROAD)	<b>Diary of Resident Engineer</b>	<b>Job Number:</b>	C-91-005-17
<b>District:</b>	01		<b>Project:</b>	M-4003 (814)

Date Monday, November 20, 2017 Weekly Report Number 32

**Controlling Item**      **HMA Surface**

**Persons Working** 13.00      **Hours Worked** 10.00

**Weather** 29-52 F, Clear, Precip = 0.00in

**Working Days Charged** 0.00      **Workable Days** 1.00

**Weekly Report Paragraph** RWD (13) - Place HMA Surface main line, Jefferson Intersection, 2nd Ct East, 2nd Ave East.

**Additional Paragraphs** Traffic Control - AM Good, PM Good

Traffic Control inspection performed  
Erosion Control inspection performed.

<b>Contract:</b>	61D60	<b>State of Illinois</b>	<b>Resident:</b>	Mehul Patel
<b>County:</b>	DUPAGE	Department of Transportation	<b>Supervisor:</b>	Jeffrey Mysliwiec
<b>Section:</b>	16-00094-00-FP	ICORS System	<b>Field Office Phone:</b>	(630)660-6180
<b>Route:</b>	FAU RTE 2667 (CHURCH ROAD)	Diary of Resident Engineer	<b>Job Number:</b>	C-91-005-17
<b>District:</b>	01		<b>Project:</b>	M-4003 (814)

**Date** Tuesday, September 11, 2018 **Weekly Report Number** 62

**Controlling Item      Punch List**

**Persons Working** 3.00      **Hours Worked** 7.00

**Weather** 58 - 79 F, Fair, Precip = 0.00in

**Working Days Charged** 0.00      **Workable Days** 0.00

**Weekly Report Paragraph** RWD (3) - Install steel adjusting rings in manhole frames. Topsoil respread 184 Church driveway. Pick up barricades. Blend topsoil around hydrants 21 and 24.

**Additional Paragraphs** Traffic Control - AM Good, PM Good