



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

May 28, 2021

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Marie T. Frey
McLaine Lomax
Nicholas Panicola Jr.
Armonda Perez

Village Clerk
Nancy Dunn

Village Manager
Evan K. Summers

Mr. Ravi Pathare
300 South Wacker Drive, Suite 620
Chicago, Illinois 60606

Re: May 25, 2021 FOIA Request

Dear Mr. Pathare:

I am pleased to help you with your May 25, 2021 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on May 25, 2021. You requested copies of the items indicated below:

"I wish to request any documents related to the property located at 611 Eagle Drive, Bensenville, IL 60106. Specifically, I am looking for documents related to tank removals, environmental inspections, fire department records, and health records for the property."

After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 69068. (1 pg.)

These are all the records found responsive to your request.

In regards underground/aboveground storage tanks and hazardous materials; please check with the Illinois Fire Marshal's Office to conduct a search of their files.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 611 EAGLE Unit:

Business name: A. A. A. COOPER TRANSPORTATION Phone: 630.350.1688

Business Owner: A. A. A. COOPER TRANSPORTATION Address: 611 EAGLE DRIVE BENSENVILLE, IL

Inspection Date: 12/30/2019 Inspector: LINDSAY LAYCOAX

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
060	EXTERIOR DOOR	"Windows, and Doors including Overhead Doors. Every exterior window, door and frame shall be kept in sound condition, good repair and weather tight."
180F	SPRINKLER SYSTEM - ANNUALLY	Need to have the Fire Sprinkler System annually certified by a licensed contractor and have the report posted in a conspicuous place next to the system. Make all noted repairs and recommendation from the sprinkler company inspection.
180M	DROP TEST - ANNUALLY	Rolling Fire Door Requirer AnnualTesting/Inspection. Provide current inspection sticker and mount on door jamb.

Additional Remarks/Comments:

Created from inspection 69067 on 07/23/2019 by 6523llay

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3414.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: Emailed results to; fred.sterling@aaacooper.com

Inspector: Lindsay Laycoax Date: December 30, 2019