



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3408
www.bensenville.il.us

VILLAGE BOARD

March 31, 2022

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Marie T. Frey
Melaine Lomax
Nicholas Pancola Jr.
Armando Perez

Village Clerk
Nancy Dunn

Village Manager
Evan K. Summers

Mr. MJ Rice
1300 South Meridian Avenue, Suite 400
Oklahoma City, Oklahoma 73108

Re: March 29, 2022 FOIA Request

Dear Mr. Rice:

I am pleased to help you with your March 29, 2022 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on March 29, 2022. You requested copies of the items indicated below:

"Please provide copies of open/unresolved zoning, building and fire code violations on file and certificates of occupancy for the property address 472 to 482 Thomas Drive Parcel: 0311400015 Provide copies of certificate of occupancies issued since March 2017 to present."


After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 70971. (2 pgs.)
- 2) Village of Bensenville Correction Notice for Inspection No. 82998. (2 pgs.)
- 3) Village of Bensenville Correction Notice for Inspection No. 68751. (1 pg.)
- 4) Village of Bensenville Correction Notice for Inspection No. 81022. (1 pg.)
- 5) Village of Bensenville Business Licenses Issued to 472 – 482 Thomas Drive Since January 1, 2008. (1 pg.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,


Corey Williamsen
Freedom of Information Officer
Village of Bensenville



VILLAGE OF BENSENVILLE FREEDOM OF INFORMATION ACT REQUEST FORM

BENSENVILLE
VILLAGE CLERK'S OFFICE

TO: COREY WILLIAMSEN

*Freedom of Information Officer
Village of Bensenville
12 S. Center Street
Bensenville, IL 60106*

FROM:

Name MJ Rice

Address 1300 S Meridian Ave Suite 400

Oklahoma City OK 73108

Phone 405-546-4391

E-Mail mj.rice@pqr.com

10861

TITLES OR DESCRIPTION OF RECORDS REQUESTED (Please Include Date of Birth and Case Number for Police Records):

Please provide copies of open/unresolved zoning, building and fire code violations on file and certificates of occupancy for the property addresses

472 to 482 Thomas Drive Parcel: 0311400015 Provide copies of certificates of occupancy issued since March 2017 to present.

Please do not exceed \$50 in fees without prior approval. Our ref # 157255-20



THIS REQUEST IS FOR A COMMERCIAL PURPOSE (*You must state whether your request is for a commercial purpose.* A request is for a “commercial purpose” if all or any part of the information will be used in any form for sale, resale, or solicitation or advertisement for sales or services. Failure to disclose whether a request is for a commercial purpose is a prosecutable violation of FOIA.)

Would like your request delivered via: E-Mail U.S. Mail Pick-Up*

**Pick-Up is available by appointment at Village Hall Monday thru Friday; between 8:00 a.m. – 5:00 p.m.*

I understand that any payment need be received before any documents are copied and/or mailed.

3/29/2022

Date

MJ Rice
Signature

All FOIA responses are posted on the Village's website. Name and address of the requestor will be made public.

The first fifty (50) pages of the request are free. The fee charge is fifteen (15) cents after the first fifty (50) pages.

Unless otherwise notified, your request for public records will be compiled within five (5) working days.

Unless otherwise notified, any request for commercial purposes will be compiled within twenty-one (21) days working days.

COREY WILLIAMSEN, FREEDOM OF INFORMATION OFFICER

Telephone: (630) 350-3404 Facsimile: (630) 350-3438

E-mail Address: FOIArequest@bensenville.il.us

For Freedom of Information Officer Use Only

3/29/22
Date Request
Received

4/5/22
Date Response
Due

4/12/22
Date Extended
Response Due

\$0-
Total Charges

3/31/22
Date Documents
Copied or Inspected

Received by Employee: _____



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 474 THOMAS Unit:

Business name:: HOLLANDER INTERNATIONAL STORAG Phone: 847-439-2140

Business Owner: HOLLANDER INTERNATIONAL STOR/ Address: 474 THOMAS BENSENVILLE, IL

Inspection Date: 10/11/2015 Inspector: TOM KNIGHT

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
060C	MEANS OF EGRESS OBSTRUCTED	The EXIT door from the warehouse (south wall) is difficult to open. Repair/replace as necessary.
120G	IDENTIFY ELECTRIC PANELS	Label each electrical panel.
120H	IDENTIFY BREAKERS	Label each breaker as to the circuit it serves.
120I	REPAIR ELECTRICAL PANELS	Repair/replace the doors to the electrical panels.
160D	EMERGENCY LIGHTS	The doors must shut and latch to remain shut. Repair/replace the damaged emergency light (column in the warehouse).
160E	EMERGENCY LIGHTS	90-minute battery back-up required. Repair/replace the emergency light in the sprinkler room.
160F	FIRE EXTINGUISHERS	90-minute battery back-up required. Provide fire extinguishers throughout the building as required per NFPA 10.
165M	SMOKE DETECTORS	Remove the plastic coverings on the smoke detectors in the east dock area (doors 3, 6, and 9).
170	SPRINKLER SYSTEM	Repair/replace the light in the sprinkler room.
170G	MISSING ESCUTCHEON RINGS	In the office area.
185	OCCUPANCY LIMITATIONS	The second floor (office mezzanine) is not approved for occupancy.

Additional Remarks/Comments:

Reinspection 71150 created on 10/11/2019
by 6523tkni

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order. Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3448.



VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 474 THOMAS Unit:

Business name:: HOLLANDER INTERNATIONAL STORAG Phone: 847-439-2140

Business Owner: HOLLANDER INTERNATIONAL STOR/ Address: 474 THOMAS BENSENVILLE, IL

Inspection Date: 10/11/2019 Inspector: TOM KNIGHT

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: Robert Wendland via email at rob@hollandermoving.com

Inspector: Tom Knight Date: 10-09-2019



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address:	476 THOMAS	Unit:	
Business name::	HOSON LOGISTICS	Phone:	630-422-7086
Business Owner:	HOSON LOGISTICS	Address:	476 THOMAS DR BENSENVILLE, IL
Inspection Date:	5/5/2021 1	Inspector:	RON HERFF
<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>	
0001	IMPROPER DISPLAY OF ADDRESS	Recommend placing business name on the front door.	
060C	MEANS OF EGRESS BLOCKED	Rear exit in the warehouse is blocked. Exit may not be blocked for any reason.	
120G	NEED ACCESS TO ELECTRIC PANEL	Need access to all electric panels	
120I	REMOVE ALL EXTENSION CORDS	May not use extention cords for other than a temporary use.	
120L	REMOVE ALL BX / ROMEX	Junction box in ceiling of warehouse on the east center wall needs to be covered.	
120N	NEED BLANKS IN PANEL	Blanks in electric panel north side of the warehouse. Electric tape can not be used as a blank.	
160E	EMERGENCY LIGHTING INOPERABLE	Check all emergency lights to make sure they operate properly.	
160G	EM/EXIT LIGHT BURNED OUT	All exit lights must be in good working condition. Check to make sure they are all operating.	
160K	EXTINGUISHERS MOUNTED WRONG	All fire extinguishers must be mounted per the manufactures specification.	
160S	MSDS SHEETS NEED TO BE POSTED	Need to locate an area to store the MSDS sheets	
170Z	OTHER	The roof above the drivers waiting area must be removed. It was installed without a permit and must be removed ASAP.	
175H	KEEP PALLETS BELOW 6 FT. HIGH	All skids must eb stored in one location. Skids may not be stored under the office area.	
180B	EXTINGUISHERS - ANNUALLY	Fire extinguishers needs to be inspected and tested annually.	
190L	KEY BOX NEEDED	Key box- for emergency access for the Fire Department.	

Additional Remarks/Comments:

Reinspection 83129 created on 05/05/2021 by 6523rher

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 476 THOMAS Unit:

Business name:: HOSON LOGISTICS Phone: 630-422-7086

Business Owner: HOSON LOGISTICS Address: 476 THOMAS DR BENSENVILLE, IL

Inspection Date: 5/5/2021 1 Inspector: RON HERFF

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Sent to Tina Chu via email @ tina.chu@hosonamerica.com

Copy of this report received by/mailed to: _____

Ron Herff

05-05-2021

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 474 Thomas Drive. Unit:

Business name: Phone:

Property Owner: Breit Industrial HS property

Address:

Inspection Date: 7-11-19

Inspector: LINDSAY LAYCOAX

Checklist #
005

Violation
VILLAGE REGULATIONS

Violation comment

When conducting business in the Village of Bensenville a current Village of Bensenville Business License must be purchased at Village Hall. Business Licence must be displayed at all times. Annual inspection or NEW BUSINESS inspection must be scheduled before occupying this unit. Contact Community & Economic Development 630.350.3411.

Additional Remarks/Comments:

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 030 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Lindsay Laycoax

7-11-19

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 482 THOMAS Unit:

Business name:: The Mens Wearhouse, Inc. Phone:

Business Owner: Address:

Inspection Date: March 24,2021 Inspector: DON TESSLER

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
005	VILLAGE REGULATIONS	Conducting business without a current 2021 Village of Bensenville Business License. Business License must be current AND BE DISPLAYED IN A PROMINET LOCATION. MUST COMPLY WITHIN 7 DAYS.

Additional Remarks/Comments:

Created from inspection 81021 on 03/24/2021 by 6523dtes

Re-inspection 03-10-2021

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____

Status	Location	DBA	Municipality	Start Date	Last License
ACTIVE	474 NORTH THOMAS DRIVE	HOLLANDER INTERNATIONAL STORAGE AND MOVI	BENSENVILLE	10/03/2019	11/01/2021
ACTIVE	474 NORTH THOMAS DRIVE	SCOTT LABORATORY SOLUTIONS, LLC	BENSENVILLE	01/29/2020	11/01/2021
INACTIVE	476 NORTH THOMAS DRIVE	CENTRAL STATES TRUCKING COMPANY	BENSENVILLE	01/01/2008	10/30/2020
ACTIVE	476 NORTH THOMAS DRIVE	HOSON LOGISTICS	BENSENVILLE	04/30/2021	11/01/2021
ACTIVE	482 NORTH THOMAS DRIVE	TAILORED SHARED SERVICES, LLC	BENSENVILLE	04/13/2021	11/01/2021