



12 South Center Street
Bensenville, IL 60106
Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

May 13, 2022

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Maria T. Frey
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

Ms. Jessica Tullier
203 North LaSalle Street, #2500
Chicago, Illinois 60601

Re: May 12, 2022 FOIA Request

Dear Ms. Tullier:

I am pleased to help you with your May 12 2022 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on May 12, 2022. You requested copies of the items indicated below:

"Any and all permits, inspection reports and code violations for property at 1285 N. Ellis St, Bensenville."


After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Permits Issued to 1285 North Ellis Street Since January 1, 2010. (1 pg.)
- 2) Village of Bensenville Correction Notice for Inspection No. 6196. (1 pg.)

These are all the records found responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,


Corey Williamsen
Freedom of Information Officer
Village of Bensenville

Location	Municipality	App Status	User Status	Application Recv'd	Project/Activity Desc Line 2
1285 NORTH ELLIS STREET	BENSENVILLE	ACTIVE	CLOSED BY INSPECTOR	10/10/2016	ABOVE GROUND TANK



Inspection Number: 6196

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
phone:630-350-3413 fax:630-350-3449

Type of Inspection: ANNUAL INSPECTION

CORRECTION NOTICE

Address: 1285 N ELLIS STREET Unit:

Business name: ROAD READY Phone: 773-286-0200

Business Owner: ROBERT W. TROCH, JR. Address:

Inspection Date & Time: Inspector: TOM KNIGHT

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
030H	INSTALL \$250 ON HANDICAP SIGN	Replace current fine sign with \$250 fine sign.
160G	EXTINGUISHERS MOUNTED WRONG	Fire extinguishers must be mounted in approved location.
180D	FIRE ALARM SYSTEM - ANNUALLY	Provide copy of current fire alarm test.
180F	EMERGENCY SHUT OFF SYSTEM - ANNUALLY	Provide a copy of current test for impact valve (emergency shut off system).
180J	BUSINESS LICENSE - ANNUALLY	BL #1898 expires 12/31/11.

Additional Remarks/Comments:

Reinspection 6197 created on 06/16/2011 by
6523tkni

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME MAY RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days from the date of this order. Appeal from this order may be made within 20 days from the above date of service. Direct such appeal for a hearing before the Bensenville Board of Appeals in writing through the Director of Inspectional Services, 12 South Center.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____