



12 South Center Street  
Bensenville, IL 60106

Office: 630.350.3404  
Fax: 630.350.3438  
[www.bensenville.il.us](http://www.bensenville.il.us)

**VILLAGE BOARD**

October 11, 2022

**President**  
Frank DeSimone

**Board of Trustees**  
Rosa Carmona  
Ann Franz  
Marie T. Frey  
McLane Lomax  
Nicholas Pancala Jr.  
Armando Perez

**Village Clerk**  
Nancy Quinn

**Village Manager**  
Evan K. Summers

**Mr. Ethan Burnett**  
35 East Wacker Drive, Suite 1250  
Chicago, Illinois 60601

Re: October 4, 2022 Commercial FOIA Request

Dear Mr. Burnett:

I am pleased to help you with your October 4, 2022 Commercial Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on October 4, 2022. You requested copies of the items indicated below:

*"Any waste water monitoring reports regarding the Property located at 1301 and 1401 Mark Street, Elk Grove Village."*

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Waste Water Monitoring Report for 1301 Mark Street, Elk Grove Village. (4 pgs.)

These are all of the documents that can be discovered responsive to your request.

The Village does not have any records regarding 1401 Mark Street, Elk Grove Village.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

  
Corey Williamsen  
Freedom of Information Officer  
Village of Bensenville



# VILLAGE OF BENSENVILLE FREEDOM OF INFORMATION ACT REQUEST FORM

BENSENVILLE  
VILLAGE CLERK'S OFFICE

TO: COREY WILLIAMSEN

Freedom of Information Officer  
Village of Bensenville  
12 S. Center Street  
Bensenville, IL 60106

FROM:

Name Ethan Burnett

Address 35 East Wacker Drive, Suite 1250

Chicago IL

Phone 312-922-1030

E-Mail eburnett@wcgrp.com

12/68

## TITLES OR DESCRIPTION OF RECORDS REQUESTED (Please Include Date of Birth and Case Number for Police Records):

Any waste water monitoring reports regarding the Proepty located at 1301 and 1401 Mark Street, Elk Grove Village

THIS REQUEST IS FOR A COMMERCIAL PURPOSE (You must state whether your request is for a commercial purpose. A request is for a "commercial purpose" if all or any part of the information will be used in any form for sale, resale, or solicitation or advertisement for sales or services. Failure to disclose whether a request is for a commercial purpose is a prosecutable violation of FOIA.)

Would like your request delivered via:  E-Mail  U.S. Mail  Pick-Up\*

\*Pick-Up is available by appointment at Village Hall Monday thru Friday; between 8:00 a.m. – 5:00 p.m.

I understand that any payment need be received before any documents are copied and/or mailed.

October 4, 2022

Date

Ethan Burnett

Signature

All FOIA responses are posted on the Village's website. Name and address of the requestor will be made public.

The first fifty (50) pages of the request are free. The fee charge is fifteen (15) cents after the first fifty (50) pages.

Unless otherwise notified, your request for public records will be compiled within five (5) working days.

Unless otherwise notified, any request for commercial purposes will be compiled within twenty-one (21) days working days.

-----  
COREY WILLIAMSEN, FREEDOM OF INFORMATION OFFICER

Telephone: (630) 350-3404 Facsimile: (630) 350-3438

E-mail Address: FOIArequest@bensenville.il.us

\*\*\*For Freedom of Information Officer Use Only\*\*\*

10/4/22  
Date Request Received

11/2/22  
Date Response Due

12/5/22  
Date Extended Response Due

\$0-  
Total Charges

10/11/22  
Date Documents Copied or Inspected

Received by Employee:

**VILLAGE OF BENSENVILLE, ILLINOIS**

Sampling Period Q1 2022

IU Name: Kerry Ingredients - 1301 Mark Street

Pollutant	Local Limit Max. Conc (mg/l)	Surcharge Threshold Conc (mg/l)	Sampling Results										Monthly Average Surcharge (mg/l)
			1/25/22	1/26/22	1/27/22	2/15/22	2/16/22	2/17/22	3/22/22	3/23/22	3/24/22	3/25/22	
Biochemical Oxygen Demand	200	200	6420	3830	2220	4370	2420	1300	519	4580	2240		3100
Total Suspended Solids	220	220	218	245	HOLD	34.6	22.0	152	172	624	72.0	613	239
Ammonia	15	15	29.7	32.8	33.4	< 0.10	0.34	84.8	6.41	8.03	2.40		22.0
Chemical Oxygen Demand	Monitor		10100	7200	4660	6740	3500	2170	513	5910	4430		
Oil & Grease	200					4.29	5.27	14.7					
pH (units)	5.0-10.0					7.02	6.01	6.88					
Total Phosphorus (as P)	Monitor					0.283	0.617	3.01					
Composite Description			Clear	yellowed	orange yellow	blue tinted	blue tinted	orange tinted	Clear	Clear	Clear	Slight yellow tint	
Grab Description			NA	NA	NA	clear	clear	orange tinted	NA	NA	NA	NA	
Grab Time (pH)			NA	NA	NA	10:01 AM	10:02 AM	11:25 AM	NA	NA	NA	NA	

**VILLAGE OF BENSENVILLE, ILLINOIS**

Sampling Period Q2 2022

IU Name: Kerry Ingredients - 1301 Mark Street

Pollutant	Local Limit Max. Conc (mg/l)	Surcharge Threshold Conc (mg/l)	Sampling Results										Monthly Average Surcharge (mg/l)
			4/19/22	4/20/22	4/21/22	5/17/22	5/18/22	5/19/22	6/14/22	6/15/22	6/16/22		
Biochemical Oxygen Demand		200	4870	1330	500	13000	6270	2260	4370	2630	1600		4092
Chemical Oxygen Demand	Monitor		11600	3620	1580	39300	14000	4520	7760	10100	3640		
Ammonia		15	0.62	3.29	55.6	41.2	20.0	25.6	24.7	10.1	12.9		21.6
Total Suspended Solids		220	146	77.0	272	2300	707	740	475	313	292		591
Oil & Grease	200					9.64	24.3	22.8					
pH (units)	5.0-10.0					6.14	8.00	7.82					
Total Phosphorus (as P)	Monitor					4.56	2.29	10.6					
Composite Description			Clear	Clear	Clear with tint	Orange and foggy	Yellow/Orange	Orange	Yellow	Yellow	Clear		
Grab Description			NA	NA	NA	Orange and foggy	Yellow/Orange	Orange	NA	NA	NA		
Grab Time (pH)			NA	NA	NA	10:51 AM	11:20 AM	11:19 AM	NA	NA	NA		

**VILLAGE OF BENSENVILLE, ILLINOIS**

Sampling Period Q3 2022

IU Name: Kerry Ingredients - 1301 Mark Street

Pollutant	Local Limit Max. Conc (mg/l)	Surcharge Threshold Conc (mg/l)	Sampling Results									Monthly Average Surcharge (mg/l)
			7/19/22	7/20/22	7/21/22	8/9/22	8/10/22	8/11/22	8/20/22	9/21/22	9/22/22	
Biochemical Oxygen Demand	200	8560	12800	20000	23300	22600	9610	6180	4310	6390	12639	
Chemical Oxygen Demand	Monitor	14700	10400	14400	46900	43900	47400	57300	117000	115000		
Ammonia	15	38.5	< 0.10	0.12	0.40	1.36	0.55	0.87	< 0.10	0.14	4.7	
Total Suspended Solids	220	1430	2640	3440	1160	1520	1500	1460	1590	4560	2144	
Oil & Grease	200				5.12	17.1	3.39					
pH (units)	5.0-10.0				5.86	6.57	5.67					
Total Phosphorus (as P)	Monitor				3.98	9.67	6.56					
Composite Description			Yellow / Clear	Yellow / Clear	Clear	Orange tint	Orange	Orange	Pink	Tan	Clear / Tan	
			NA	NA	NA	Orange tint	Orange	Orange	NA	NA	NA	
			NA	NA	NA	2:42 PM	2:45 PM	2:43 PM	NA	NA	NA	

VILLAGE OF BENSENVILLE, ILLINOIS

Sampling Period Q4 2021

IU Name: Kerry Ingredients - 1301 Mark Street

Pollutant	Local Limit Max. Conc (mg/l)	Surcharge Threshold Conc (mg/l)	Sampling Results										Monthly Average Surcharge (mg/l)
			10/5/21	10/6/21	10/7/21	11/16/21	11/17/21	11/18/21	12/14/21	12/15/21	12/16/21		
Biochemical Oxygen Demand		200	7000	8000	12000	10000	3000	8000	9500	7500	11800		8533
Chemical Oxygen Demand	Monitor		9390	14400	17700	22600	6810	15100	18100	12700	19000		
Ammonia		15	1.38	< 0.10	< 0.10	< 0.10	40.7	0.30	< 0.10	< 0.10	< 0.10		4.78
Total Suspended Solids		220	220	56	130	266	536	1930	61	39	35		364
Oil & Grease	200					< 13	40	< 10					
pH (units)	5.0-10.0					6.59	6.09	5.40					
Total Phosphorus (as P)	Monitor					4.88	9.28	3.00					
Composite Description			Cloudy None	Cloudy None	Slightly Cloudy None	Clear None	Cloudy Beige	Cloudy Beige	Clear Pale Blue Tint	Clear Clear	Clear Clear		
Grab Description			NA	NA	NA	Cloudy White	Cloudy Pale Orange/Beige	Clear Clear	NA	NA	NA		
Grab Time (pH)			NA	NA	NA	10:10	10:05	10:55	NA	NA	NA		