



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

July 12, 2023

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Amy Franz
Marie T. Frey
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

Mr. Dan Nix
638 East Golf Road
Arlington Heights, Illinois 60005

Re: July 11, 2023 FOIA Request

Dear Mr. Nix:

I am pleased to help you with your July 11, 2023 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on July 11, 2023. You requested copies of the items indicated below:

"Requesting Building Permit #12604 approval documentation."

Your FOIA is hereby granted in full with the enclosed records. No redactions have been made.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville

VILLAGE OF BENSENVILLE

Department of Community and Economic Development
12 S. Center St. Bensenville, IL 60106
Phone: 630.350.3413 Fax: 630.350.3449

PERMIT APPLICATION

Application Number
12604

CHECK ONE: RESIDENTIAL MULTI-RESIDENTIAL NON-RESIDENTIAL

146 W. Irving Park Rd., Bensenville, IL

1

C-1

SITE ADDRESS

UNIT No.

P.I.N.

ZONING DISTRICT

Fire Alarm Installation

\$ 4,800.00

DESCRIPTION OF WORK

Name of Business on Site (non-residential): **Wingstop**

ESTIMATED COST

GENERAL CONTRACTOR: **Customized Protection Services, Inc.**

18325

ADDRESS: **830 Warren Ave.,**

CITY, STATE & ZIP: **Downers Grove, IL 60515**

PHONE: **630-963-2410**

E-MAIL: **mjacobo@customizedfx.com jrodriguez@customizedfx.com**

IF NECESSARY, ADDITIONAL LICENSED CONTRACTORS MUST COMPLETE & ATTACH LICENSE CERTIFICATE & BOND ON PAGE 2

OWNER AND APPLICANT INFORMATION

No error or omission in either the plans or application in having the work completed in any other manner than that it is in compliance with the approved plans and the applicable codes and ordinances of the Village of Bensenville and the State of Illinois. All work shall be completed, inspected and approved as required and no occupancy or use of the space shall be permitted until approved in writing by the Department of Community and Economic Development. The applicant shall be responsible for all fees associated with the instant permit, including but limited to cancellation fees, plan review fees, and re-inspection fees. Understanding the preceding statements, I hereby agree to comply and declare that to the best of my knowledge and belief the information provided is true and accurate.

Jason Rodriguez -Customized Protection :

3/01/2021

Applicant's Name (Print)

830 Warren Ave.,

Address

mjacobo@customizedfx.com

Applicant's Email Address

Applicant's Signature

Downers Grove, IL 60515

City, State & ZIP

Date

630-963-2410

Day Time Phone

Correspondence and escrow refunds can only be completed if the address of the applicant is kept current, which is applicant's responsibility.

I hereby authorize the above listed applicant to complete the provisions of the applicable code and ordinances of this permit.

Brian Properties, Inc. as Agent

11/15/2022

Property Owner's Name (Print)

2045 S Arlington heights Rd Suite 100

Address

Property Owner's Signature

Arlington heights, IL 60005

City, State & ZIP

Date

847-640-1500

Day Time Phone

OFFICE USE ONLY

BUILDING INFORMATION

- New Construction Addition
 Alteration Accessory

Storm-water Permit Required Yes No

Milestone Dates:

11-15-22 Applied

Fees:

ESCROW \$ **180⁰⁰**

11-18-22 Approved

APPLICATION \$ **100⁰⁰**

11-23-22 Issued

PLAN REVIEW \$ **27⁰⁰**

05-23-23 Expires


INSPECTIONS (1 X \$35 / \$45) \$ **45⁰⁰**

Fire Alarm Reg. OTHER \$ **150⁰⁰**

OTHER \$ **8⁰⁰**

TOTAL FEES DUE \$ **F 502⁰⁰**

PAID BY:



APPROVED BY: *[Signature]*

FILE COPY
Village of Bensenville

VILLAGE OF BENSENVILLE

Department of Community and Economic Development

CONDITIONS OF THE PERMIT

SITE LOCATION: 146 WEST IRVING PARK ROAD

INTENDED USE: C-1

APPLICATION NO: 12604

APPLICATION TYPE: FIRE ALARM SYSTEM C/F

DESCRIPTION OF WORK: FIRE ALARM SYSTEM

1. All work whether approved or not shall be in compliance with the applicable codes and ordinances.
2. Contact the Community and Economic Development Department 24 hours in advance at 630-350-3413 for any necessary inspections.
3. No work except what has been approved or required shall be permitted through the execution of this permit. No changes to the approved plans will be permitted without authorization by the Department of Community and Economic Development in writing.
4. THESE PLANS & CONDITIONS MUST BE AT THE JOB SITE AND AVAILABLE FOR EACH INSPECTION. If the approved copy is not available, the inspection will not be conducted and the report shall be marked "Not Approved." DO NOT REMOVE THESE CONDITIONS FROM THE PLANS.
5. SPECIAL CONDITIONS TO APPLICATION NUMBER 146 WEST IRVING PARK ROAD

PLAN EXAMINER REVIEW

Kitchen Hood- Ansul System. Shall be installed per manufacturer's specification.
Balloon test and exhaust systems shall be inspected

Fire alarm system needs to be installed per NFPA 72; 2002 Edition (PERMIT NEEDED).

Fire alarm acceptance test shall be witnessed by Village Inspector. Call 1-630-350-3413 to schedule.

Low voltage wiring shall be protected in all vertical applications.
Horizontal runs need to be supported through bridging rings.

Wiring shall not be connected in any way to any plumbing, gas, water, sprinkler lines, etc.

Zone map, no less than 8.5 inches x 11 inches shall be permanently located near the fire alarm control panel, and near annunciation panel if one is required.

Zone list shall also be provided in same location(s).

Inspection and approval from the village electrical inspector is required before a request for a alarm acceptance test can be scheduled.

Call 630-350-3413 to schedule electrical inspection.

Provide a copy of certificate of completion, at time of acceptance test.

Once electrical inspection is approved, call 1-630-350-3413 to schedule alarm acceptance test.

Key box shall be installed on the address side of the building.

Order on line at www.knoxbox.com, or call Anderson Lock at 1-847-296-1157.

The battery back-up shall provide 60 hours of stand-by power and 5 minutes of load alarm condition to all equipment essential to the fire alarm system operation. Batteries shall be permanently marked with the month and the year of manufacture


An exterior rated horn/strobe alarm device shall be installed on the exterior of all buildings to identify the building in alarm from a distance, the location of which shall be determined by the fire code official.

All fire alarm control panels or full function annunciation panels shall be installed within 10'-0" of the main entrance unless otherwise approved by the fire code official.

All work must be performed in a neat and workmanlike manner by persons who are skilled in their trades in full performance with the Village Code. All work must be inspected in accordance with the inspection lists provided with this permit. Owner/Contractor is responsible to expose any work concealed without the required inspection and approval.

The completion of this project and the bond refund process is subject to the final inspection and approval by the Village Inspector. NOTE: All debris and landscaping must be returned to original conditions prior to final inspection.

Having read and understood the preceding conditions, I hereby agree to comply with them.


SIGNATURE

Mercedes E. Jacobs
NAME (PRINT)

11/23/22
DATE

Ron Herff

FILE COPY

Village of Bensenville

From: Ron Herff
Sent: Friday, November 18, 2022 11:14 AM
To: 'mjacobo@customizedfx.com'
Subject: Fire Alarm Permit 146 W Irving Park Rd, Bensenville IL

Mr. Rodriguez, your fire alarm permit for 146 W Irving Park RD Bensenville IL is ready for pick up at the Bensenville Village Hall 12 S Center Bensenville IL.

FEES:

Escrow----- \$ 180.00
Application, review and inspections \$ 322.00

Total:----- \$ 502.00

Ron Herff
Deputy Director/Fire Marshall
Community & Economic Development

Village of Bensenville
12 S Center Street
Bensenville, IL 60106


Office: 630-594-1009
Cell: 630-880-9622
Fax: 630-350-3449



Customized Protection Services, Inc.

830 Warren Avenue
Downers Grove, IL 60515
630-963-2410
630-963-6305 fax

FILE COPY
Village of Bensenville



Date: November 15, 2022.

Submittal Documentation for Fire Alarm Installation Permit

PROJECT	COMPANY INFORMATION
Wingstop	Customized Protection Services, Inc
146 W. Irving Park Rd. Bensenville, IL 60106	Jason Rodriguez ✉ jrodriguez@customizedfx.com 708-785-9716
	Mercedes Jacobo ✉ mjacobo@customizedfx.com

ENCLOSED

- Plan
- Cut Sheets
- Building Permit Application
- Illinois State License

NOTES:

- 2 Sets of submittals

Sincerely
Mercedes Jacobo.
Office Manager

Committed to Perfection in Property Protection
State of Illinois Alarm Contractors License #127-001475

State of Illinois

Department of Financial and Professional Regulation Division of Professional Regulation

LICENSE NO.
127.001475
124.001481

The person, firm, or corporation whose name appears on this certificate has complied with the provisions of the Illinois Statutes and/or rules and regulations and is hereby authorized to engage in the activity as indicated below.

EXPIRES:
08/31/2023

LICENSED PRIVATE ALARM CONTRACTOR AGENCY



CUSTOMIZED PROTECTION SERVICES INC
830 WARREN AVE
DOWNERS GROVE, IL 60515-3731



DEBORAH HAGAN
SECRETARY

CECILIA ABUNDIS
ACTING DIRECTOR

15037785

The official status of this license can be verified at www.idfpr.com

Cut on Dotted Line

For future reference, IDFPR is now providing each person/business a unique identification number, 'Access ID', which may be used in lieu of a social security number, date of birth or FEIN number when contacting the IDFPR. Your Access ID is: 3651709

FILE COPY
Village of Bensenville

FL-PS6(C) & FL-PS10(C)

6 Amp and 10 Amp, 24 Volt
Remote Power Supplies


Village of Bensenville

Fire-Lite® Alarms
by Honeywell

Power Supplies/Accessories

General

The PS Series is a remote power supply line from Fire-Lite Alarms and is a direct replacement for the FCPS-24FS6/8 Series. The FL-PS6(C) is a 6 amp and the FL-PS10(C) is a 10 amp, remote power supply with battery charger that may be connected to any 12 or 24 volt fire alarm control panel (FACP) or used as a standalone power supply. The PS Series provides 24 VDC power for NACs (notification appliance circuits) configured as either Class B or Class A (requires the ZNAC-PS option card) with multiple sync protocol options. The PS Series also provides auxiliary power, constant or resettable, suited for detectors, annunciators, door holders, and other fire alarm system peripherals. The PS Series cabinet can hold two 7 AH or 18 AH batteries and can charge up to 33 AH batteries in a separate cabinet.



Features

- Up to five (6 amp model) or seven (10 amp model) independently-configurable, power-limited output circuits for:
 - Class B and/or Class A NACs
 - Class B and/or Class A resettable or non-resettable 24V auxiliary power
 - door holder power
 - Converts from Class B to Class A wiring without losing any outputs using the ZNAC-PS converter card (sold separately)
 - Optimal for powering four-wire smoke detectors, annunciators, and other system peripherals requiring regulated power
 - Configurable for ANSI® Temporal 3 or Temporal 4 coded output
 - UL-Listed NAC synchronization using System Sensor®, Wheellock®, Gentex®, or AMSECO® appliances
 - Synchronization can be triggered from FACP NAC/remote sync outputs, cascaded power supply, or a control module, single or multi, which may be housed within the power supply cabinet
 - Ability to cascade up to four power supplies
 - Two (6 amp model) or three (10 amp model) fully-isolated input control circuits which can be programmed to any output
 - Two Form C normally-closed trouble relays for AC Trouble and General Trouble, Ground Fault relay available on Canadian models only
 - 6 or 10 amp full load output, respectively, with 3 A maximum/circuit
 - Individual NAC power and trouble LEDs for diagnostic efficiency
 - Trouble history modes for diagnostic support
 - Wide range end-of-line supervision value (normal: 2K-27K ohms)
 - Selectable earth fault detection (enable or disable)
 - AC trouble report delay timer
 - Completely configurable via onboard DIP switches, no extra software required
 - Self-contained in compact, locking cabinet constructed of heavy gauge steel with a corrosion-resistant powder coat chip and scratch-resistant finish
 - Cabinet designed with ten double knockouts and a removable door for ease of installation and wiring
 - Includes integral battery charger capable of charging up to 33 AH batteries
 - Cabinet can house two 7 AH or 18 AH batteries
- Battery charger may be disabled via DIP switch for applications requiring larger batteries and external battery charger
 - Removable terminal blocks accommodate up to 12 AWG (3.1mm²) wire
 - Works with any UL 864 FACP which utilizes an industry-standard reverse-polarity notification circuit
 - Optional devices include addressable control, monitor, and relay modules and power-supervision relay (EOLR-1)

Standards and Codes


The FL-PS Series comply with the following standards:

- NFPA 72 National Fire Alarm Code
- UL 864 Standard for Control Units for Fire Alarm Systems (NAC expander mode), 10th Edition
- UL 1481 Power Supplies for Fire Alarm Systems
- IBC 2009 (when using SEISKIT-MULTI-1)
- CBC 2007 (when using SEISKIT-MULTI-1)

Agency Listings and Approvals

These listings and approvals apply to the modules specified in this document. In some cases, certain modules or applications may not be listed by certain approval agencies, or listing may be in process. Consult factory for latest listing status.

- UL Listed: S2424
- ULC Listed: S2424 (FL-PS6/10C)
- CSFM Approved: 7315-0075:0510
- FDNY Approved
- FM Approved



SYSTEM SPECIFICATIONS

Primary (AC) Power:

- **FL-PS6(C):** 120 VAC, 50/60 Hz, 5.0A maximum
- **FL-PS10(C):** 120VAC, 50/60 Hz, 6.2 A maximum
- **Wire Size:** #12-14 AWG with 600 V insulation

Command Input Circuit:

- **Trigger Input Voltage:** 9 to 32 VDC
- **Trigger Current:** 2.0 mA (16 - 32 V); Per Input: 1.0 mA (9 - 16 V)

Trouble Contact Rating: 4 A at 24 VDC

Output Circuits:

- 24 VDC filtered, regulated
- **FL-PS6:** TB8-TB9 – 1A Regulated, 3A special applications; TB10-TB12 – 0.3A Regulated, 3A special applications
- **FL-PS10:** TB8-TB11 – 1.5A Regulated, 3A special applications; TB12-TB14 – 0.3A Regulated, 3A special applications
- 6.0 A (FL-PS6) or 10.0 A (FL-PS10) maximum total continuous current for all outputs

Secondary Power (Battery) Charging Circuit:

- Supports lead-acid batteries only
- Float-charge voltage: 27.6 VDC
- Maximum current charge: 1.5 A
- Maximum battery capacity: 18 AH (inside cabinet)
- Maximum battery charging capacity: 33 AH (external cabinet)

Physical:

- **Dimensions:** 20.0" H x 14.5" W x 3.5" D (cm: 50.8H x 36.83W x 8.9D)
- **Weight:** with two 7Ah batteries is 24 pounds (10.9 kg), with two 18 AH batteries is 39 pounds (17.7 kg)

Ordering Information

FL-PS6: 6.0 A, 120 VAC remote charger power supply in a lockable, metal enclosure

FL-PS6C: Same as above, ULC-listed model

FL-PS10: 10.0 A, 120 VAC remote charger power supply in a lockable, metal enclosure

FL-PS10C: Same as above, ULC-listed model

ZNAC-PS: Optional Class A output converter module

CMF-300: Addressable Control Module for one Class B or Class A zone of supervised, polarized Notification Appliances. Notification Appliance Circuit option requires external 24 VDC to power notification appliances.

CRF-300: Addressable relay module containing two isolated sets of Form-C contacts, which operate as a DPDT switch

MMF-300: Addressable Monitor Module for one zone of normally open dry-contact initiating devices. Includes plastic cover plate and end-of-line resistor. Module may be configured for either a Class B or Class A IDC.

MDF-300: Dual Monitor Module. Same as MMF-300 except it provides two inputs for Class B wiring only

CDRM-300: Provides two monitored inputs and two Form-C relays. Functions in Class B wiring only.

CMF-300-6: Six-circuit supervised control module

CRF-300-6: Six Form-C relay control module

EOLR-1: 12/24 VDC end-of-line relay for monitoring four-wire smoke detector power

BAT-1270-BP: Battery, 12 volt, 7.0 AH, 5-pack (two required).

BAT-12180-BP: Battery, 12 volt, 18AH, 2-pack

BAT-12330: Battery, 12 volt, 33AH

SEISKIT-MULTI-1: Seismic kit for the FL-PS Series. Includes bracket and hardware for two 7AH or two 18AH batteries.

Fire-Lite® Alarms and System Sensors® are registered trademarks of Honeywell International, Inc. Wheelock® is a registered trademark of Cooper Technologies Company. Gentex® is a registered trademark of Gentex Corporation. AMSECO® is a registered trademark of Potter Electric Signal Company, LLC. ANSI® is a registered trademark of the American National Standards Institute, Inc. ©2020 by Honeywell International Inc. All rights reserved. Unauthorized use of this document is strictly prohibited.

This document is not intended to be used for installation purposes.

We try to keep our product information up-to-date and accurate.

We cannot cover all specific applications or anticipate all requirements.

All specifications are subject to change without notice.



For more information, contact Fire-Lite Alarms. Phone: (800) 627-3473, FAX: (877) 699-4105.
www.firelite.com



Country of Origin: USA



Indoor Selectable-Output Horns, Strobes, and Horn Strobes for Wall Applications

System Sensor L-Series audible visible notification products are rich with features guaranteed to cut installation times and maximize profits with lower current draw and modern aesthetics.

Features

- Updated Modern Aesthetics
- Small profile devices for Horns and Horn Strobes
- Plug-in design with minimal intrusion into the back box
- Tamper-resistant construction
- Automatic selection of 12- or 24-volt operation at 15 and 30 candela
- Field-selectable candela settings on wall units: 15, 30, 75, 95, 110, 135, and 185
- Horn rated at 88+ dBA at 16 volts
- Rotary switch for horn tone and two volume selections
- Mounting plate for all standard and all compact wall units
- Mounting plate shorting spring checks wiring continuity before device installation
- Electrically Compatible with legacy SpectrAlert and SpectrAlert Advance devices
- Compatible with MDL3 sync module
- Listed for wall mounting only

Agency Listings




55512
54011



FM Approved except
for ALERT models
3067355, 3067072



7125-1633-054
7135-1633-053



The System Sensor L-Series offers the most versatile and easy-to-use line of horns, strobes, and horn strobes in the industry with lower current draws and modern aesthetics. With white and red plastic housings, standard and compact devices, and plain FIRE, and FUEGO-printed devices, System Sensor L-Series can meet virtually any application requirement.

The L-Series line of wall-mount horns, strobes, and horn strobes include a variety of features that increase their application versatility while simplifying installation. All devices feature plug-in designs with minimal intrusion into the back box, making installations fast and foolproof while virtually eliminating costly and time-consuming ground faults.

To further simplify installation and protect devices from construction damage, the L-Series utilizes a universal mounting plate for all models with an onboard shorting spring, so installers can test wiring continuity before the device is installed.

Installers can also easily adapt devices to a suit a wide range of application requirements using field-selectable candela settings, automatic selection of 12- or 24-volt operation, and a rotary switch for horn tones with two volume selections.

L-Series Specifications

Architect/Engineer Specifications

General

L-Series standard horns, strobes, and horn strobes shall mount to a standard 2 x 4 x 1 7/8-inch back box, 4 x 4 x 1 1/8-inch back box, 4-inch octagon back box, or double-gang back box. L-Series compact products shall mount to a single-gang 2 x 4 x 1 1/8-inch back box. A universal mounting plate shall be used for mounting ceiling and wall products for all standard models and a separate universal mounting plate shall be used for mounting wall compact models. The notification appliance circuit wiring shall terminate at the universal mounting plate. Also, L-Series products, when used with the Sync•Circuit™ Module accessory, shall be powered from a non-coded notification appliance circuit output and shall operate on a nominal 12 or 24 volts. When used with the Sync•Circuit Module, 12-volt-rated notification appliance circuit outputs shall operate between 8.5 and 17.5 volts; 24-volt-rated notification appliance circuit outputs shall operate between 16.5 and 33 volts. Indoor L-Series products shall operate between 32 and 120 degrees Fahrenheit from a regulated DC or full-wave rectified unfiltered power supply. Strobes and horn strobes shall have field-selectable candela settings including 15, 30, 75, 95, 110, 135, and 185.

Strobe

The strobe shall be a System Sensor L-Series Model _____ listed to UL 1971 and shall be approved for fire protective service. The strobe shall be wired as a primary-signaling notification appliance and comply with the Americans with Disabilities Act requirements for visible signaling appliances, flashing at 1 Hz over the strobe's entire operating voltage range. The strobe light shall consist of a xenon flash tube and associated lens/reflector system.

Horn Strobe Combination

The horn strobe shall be a System Sensor L-Series Model _____ listed to UL 1971 and UL 464 and shall be approved for fire protective service. The horn strobe shall be wired as a primary-signaling notification appliance and comply with the Americans with Disabilities Act requirements for visible signaling appliances, flashing at 1 Hz over the strobe's entire operating voltage range. The strobe light shall consist of a xenon flash tube and associated lens/reflector system. The horn shall have two audibility options and an option to switch between a temporal three pattern and a non-temporal (continuous) pattern. These options are set by a multiple position switch. The horn on horn strobe models shall operate on a coded or non-coded power supply.

Synchronization Module

The module shall be a System Sensor Sync•Circuit model MDL3 listed to UL 464 and shall be approved for fire protective service. The module shall synchronize SpectrAlert strobes at 1 Hz and horns at temporal three. Also, while operating the strobes, the module shall silence the horns on horn strobe models over a single pair of wires. The module shall mount to a 4 11/16 x 4 11/16 x 2 1/8-inch back box. The module shall also control two Style Y (class B) circuits or one Style Z (class A) circuit. The module shall synchronize multiple zones. Daisy chaining two or more synchronization modules together will synchronize all the zones they control. The module shall not operate on a coded power supply.

Physical/Electrical Specifications

Standard Operating Temperature	32°F to 120°F (0°C to 49°C)
Humidity Range	10 to 93% non-condensing
Strobe Flash Rate	1 flash per second
Nominal Voltage	Regulated 12 DC or regulated 24 DC/FWR ^{1,2}
Operating Voltage Range	8 to 17.5 V (12 V nominal) or 16 to 33 V (24 V nominal)
Operating Voltage Range MDL3 Sync Module	8.5 to 17.5 V (12 V nominal) or 16.5 to 33 V (24 V nominal)
Input Terminal Wire Gauge	12 to 18 AWG
Wall-Mount Dimensions (including lens)	5.6" L x 4.7" W x 1.91" D (143 mm L x 119 mm W x 49 mm D)
Compact Wall-Mount Dimensions (Including lens)	5.26" L x 3.46" W x 1.91" D (133 mm L x 88 mm W x 49 mm D)
Horn Dimensions	5.6" L x 4.7" W x 1.25" D (143 mm L x 119 mm W x 32 mm D)
Compact Horn Dimensions	5.25" L x 3.45" W x 1.25" D (133mm L x 88mm W x 32mm D)

1. Full Wave Rectified (FWR) voltage is a non-regulated, time-varying power source that is used on some power supply and panel outputs.

2. Strobe products will operate at 12 V nominal only for 15 cd and 30 cd.

UL Current Draw Data

UL Max. Strobe Current Draw (mA RMS)			UL Max. Horn Current Draw (mA RMS)		
Candela Range	8-17.5 Volts		16-33 Volts		FWR
	Candela	DC	DC	DC	
15	88	43	60		
	143	63	83		
	N/A	107	136		
	N/A	121	155		
	N/A	148	179		
	N/A	172	209		
	N/A	222	257		
3.1 KHz Coded					
3.1 KHz Non-Temporal					
3.1 KHz Temporal					
Non-Temporal					
Temporal					
135					
185					


UL Max. Current Draw (mA RMS), 2-Wire Horn Strobe, Candela Range (15-115 cd)									
DC Input	8-17.5 Volts				16-33 Volts				185cd
	15cd	30cd	15cd	30cd	75cd	95cd	110cd	135cd	
Temporal High	98	158	54	74	121	142	162	196	245
Temporal Low	93	154	44	65	111	133	157	184	235
Non-Temporal High	106	166	73	94	139	160	182	211	262
Non-Temporal Low	93	156	51	71	119	139	162	190	239
3.1K Temporal High	93	156	53	73	119	140	164	190	242
3.1K Temporal Low	91	154	45	66	112	133	160	185	235
3.1K Non-Temporal High	99	162	69	90	135	157	175	208	261
3.1K Non-Temporal Low	93	156	52	72	119	138	162	192	242
16-33 Volts									
FWR Input	15cd	30cd	75cd	95cd	110cd	135cd	185cd		
	83	107	156	177	198	234	287		
Temporal Low	68	91	145	165	185	223	271		
Non-Temporal High	111	135	185	207	230	264	316		
Non-Temporal Low	79	104	157	175	197	235	283		
3.1K Temporal High	81	105	155	177	196	234	284		
3.1K Temporal Low	68	90	145	166	186	222	276		
3.1K Non-Temporal High	104	131	177	204	230	264	326		
3.1K Non-Temporal Low	77	102	156	177	199	234	291		

Horn Tones and Sound Output Data

Horn and Horn Strobe Output (dBA)					
Switch Position	Sound Pattern	8-17.5 Volts		16-33 Volts	
		dB	DC	DC	FWR
1	Temporal	High	84	89	89
2	Temporal	Low	75	83	83
3	Non-Temporal	High	85	90	90
4	Non-Temporal	Low	76	84	84
5	3.1 KHz Temporal	High	83	88	88
6	3.1 KHz Temporal	Low	76	82	82
7	3.1 KHz Non-Temporal	High	84	89	89
8	3.1 KHz Non-Temporal	Low	77	83	83
9*	Coded	High	85	90	90
10*	3.1 KHz Coded	High	84	89	89

* Settings 9 and 10 are not available on the 2-wire horn strobes.

L-Series Dimensions



L-Series Ordering Information

Model	Description	Model	Description
Wall Horn Strobes			
P2RL	2-Wire, Horn Strobe, Red	HRL	Horn, Red
P2WL	2-Wire, Horn Strobe, White	HWL	Horn, White
P2GRL	2-Wire, Compact Horn Strobe, Red	HGRL	Compact Horn, Red
P2GWL	2-Wire, Compact Horn Strobe, White	HGWL	Compact Horn, White
P2RL-P	2-Wire, Horn Strobe, Red, Plain	Accessories	
P2WL-P	2-Wire, Horn Strobe, White, Plain	TR-2	Universal Wall Trim Ring Red
P2RL-SP	2-Wire, Horn Strobe, Red, FUEGO	TR-2W	Universal Wall Trim Ring White
P2WL-SP	2-Wire, Horn Strobe, White, FUEGO	SBBRL	Wall Surface Mount Back Box, Red
Wall Strobes		SBBWL	Wall Surface Mount Back Box, White
SRL	Strobe, Red	SBBGRL	Compact Wall Surface Mount Back Box, Red
SWL	Strobe, White	SBBGWL	Compact Wall Surface Mount Back Box, White
SGRL	Compact Strobe, Red		
SGWL	Compact Strobe, White		
SRL-P	Strobe, Red, Plain		
SWL-P	Strobe, White, Plain		
SRL-SP	Strobe, Red, FUEGO		
SWL-CLR-ALERT	Strobe, White, ALERT		

Notes:

All -P models have a plain housing (no "FIRE" marking on cover)
 All -SP models have "FUEGO" marking on cover
 All -ALERT models have "ALERT" marking on cover



3825 Ohio Avenue • St. Charles, IL 60174
 Phone: 800-SENSOR2 • Fax: 630-377-6495
www.systemsensor.com

©2017 System Sensor
 Product specifications subject to change without notice. Visit [systemsensor.com](http://www.systemsensor.com) for current product information, including the latest version of this data sheet.
 AVDS02S03 • 07/17

2420 Vantage Drive
 Elgin, IL 60124
 (847) 428-7010

№ 405193

INSPECTION REPORT
BENSENVILLE IL
 (Municipality)

Contractor/Owner:	COMPUTIMIZE Protection			Date:	3-6-23
Address:	146 IRVING PARK Rd			Permit No.:	12604
Location:				Project Code No.:	98044
Time:	10:15 - 10:45				
	(Building)	(Mechanical)	(Electrical)	(Plumbing)	(Other)

- | | | | | |
|--|---|---|--|--|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Insulation | <input type="checkbox"/> Concrete Pour | <input type="checkbox"/> Building | |
| <input type="checkbox"/> Foundation | <input type="checkbox"/> Electric Service | <input checked="" type="checkbox"/> Fire Alarm | <input type="checkbox"/> Mechanical | |
| <input type="checkbox"/> Foundation Backfill | <input type="checkbox"/> Zoning | <input type="checkbox"/> Fire Suppression | <input checked="" type="checkbox"/> Electrical | |
| <input type="checkbox"/> Other: _____ | | | <input type="checkbox"/> Plumbing | |
| <input type="checkbox"/> Underground | | <input type="checkbox"/> Rough | <input checked="" type="checkbox"/> Final | <input type="checkbox"/> Re-Inspection |
| <input type="checkbox"/> 1 & 2 Family | | <input checked="" type="checkbox"/> Commercial/Industrial | <input type="checkbox"/> Multi-Family | <input type="checkbox"/> Mobile Home |

Inspection Comments:

LINE VOLTAGE TO ALARM Panel

OPCD Good

PANEL LABEL Good

LOCK OUT Good

Received By:

Re-Inspection Required Approved As Noted


 (Signature)

Inspector:

Approved

Printed Name:


 (Signature)

Printed Name:

daniel gomez

NOTIFIED: Owner Contractor Applicant Agent
 BY: Mail Fax Inspection Report Posted

