



BENSENVILLE VILLAGE CLERK'S OFFICE

12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD January 2018

January 22, 2025

President
Frank DeSimone

Village Clerk
Nancy Quinn

Village Manager
Daniel Schulze

Re: January 16, 2025 FOIA Request

Dear Mr. Samovsky:

I am pleased to help you with your January 16, 2025 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on January 16, 2025. You requested copies of the items indicated below:

"Copies of all annual Business Licenses for Toy Barn Inc. since 2018. Copies of all tickets or violations issued to Toy Barn Inc. since 2018. Copies of all Public complaints issued for Toy Barn Inc. since 2018."

Enclosed are the records found responsive to your FOIA request. No redactions have been made.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville



VILLAGE OF BENSENVILLE FREEDOM OF INFORMATION ACT REQUEST FORM



TO: COREY WILLIAMSEN
Freedom of Information Officer
Village of Bensenville
12 S. Center Street
Bensenville, IL 60106

FROM: Name Andy Samansky
Address 1081 Entry Dr
Bensenville IL
Phone 847-873-9649
E-Mail toybarnsales@gmail.com

17616

TITLES OR DESCRIPTION OF RECORDS REQUESTED (Please Include Date of Birth and Case Number for Police Records):

Copies of all annual Business Licenses for Toy Barn Inc since 2018
Copies of all tickets or violations issued to Toy Barn Inc since 2018
Copies of all public complaints issued for Toy Barn Inc Since 2018

THIS REQUEST IS FOR A COMMERCIAL PURPOSE (You must state whether your request is for a commercial purpose. A request is for a "commercial purpose" if all or any part of the information will be used in any form for sale, resale, or solicitation or advertisement for sales or services. Failure to disclose whether a request is for a commercial purpose is a prosecutable violation of FOIA.)

Would like your request delivered via: E-Mail U.S. Mail Pick-Up*

*Pick-Up is available by appointment at Village Hall Monday thru Friday; between 8:00 a.m. - 5:00 p.m.

I understand that any payment need be received before any documents are copied and/or mailed.

1-16-25
Date

Alley
Signature

All FOIA responses are posted on the Village's website. Name and address of the requestor will be made public.

The first fifty (50) pages of the request are free. The fee charge is fifteen (15) cents after the first fifty (50) pages.

Unless otherwise notified, your request for public records will be compiled within five (5) working days.

Unless otherwise notified, any request for commercial purposes will be compiled within twenty-one (21) days working days.

COREY WILLIAMSEN, FREEDOM OF INFORMATION OFFICER

Telephone: (630) 350-3404 Facsimile: (630) 350-3438

E-mail Address: FOIArequest@bensenville.il.us

For Freedom of Information Officer Use Only

1/16/25
Date Request Received

1/24/25
Date Response Due

1/31/25
Date Extended Response Due

00 -
Total Charges

1/22/25
Date Documents Copied or Inspected

Received by Employee: _____



BENSENVILLE

WHERE OPPORTUNITY TAKES OFF

Thank you for purchasing your 2018 Business License

Watch for one of our Village Inspectors to visit you soon for your annual inspection.

TOY BARN INC
1081 ENTRY DR
BENSENVILLE, IL 60106

"We are here to help"
Questions?
Call us at 630.350.3413

DISPLAY IN A PROMINENT
LOCATION


VILLAGE OF BENSENVILLE
BUSINESS LICENSE

LICENSE NUMBER
5296

20


TOY BARN INC
1081 ENTRY DR
BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

18



Village President

Non-Transferable
Expiration date: 12/31/18



Director of Community and Economic
Development

For your records

VILLAGE OF BENSENVILLE
BUSINESS LICENSE

LICENSE NUMBER
5296

20


TOY BARN INC
1081 ENTRY DR
BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

18



Village President

Non-Transferable
Expiration date: 12/31/18



Director of Community and Economic
Development



BENSENVILLE

WHERE OPPORTUNITY TAKES OFF

Thank you for purchasing your 2019 Business License

Watch for one of our Village Inspectors to visit you soon for your annual inspection.

TOY BARN INC
1081 ENTRY DR
BENSENVILLE, IL 60106

"We are here to help"
----- Questions? -----
Call us at 630.350.3413

DISPLAY IN A PROMINENT
LOCATION

VILLAGE OF BENSENVILLE
BUSINESS LICENSE

LICENSE NUMBER
5296

20


TOY BARN INC
1081 ENTRY DR
BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

19



Village President

Non-Transferable
Expiration date: 12/31/19



Director of Community and Economic
Development

For your records

VILLAGE OF BENSENVILLE
BUSINESS LICENSE

LICENSE NUMBER
5296

20


TOY BARN INC
1081 ENTRY DR
BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

19



Village President

Non-Transferable
Expiration date: 12/31/19



Director of Community and Economic
Development



BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

Thank you for purchasing your
2021 Business License

Watch for one of our Village Inspectors to visit you soon for your annual inspection.

TOY BARN INC

1081 ENTRY DRIVE
BENSENVILLE, IL 60106

"We are here to help"
----- Questions? -----
Call us at 630.350.3413

For your records

VILLAGE OF BENSENVILLE
BUSINESS LICENSE

LICENSE NUMBER
5296

20



Village President

TOY BARN INC
1081 ENTRY DR

21

BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

Non-Transferable
Expiration date: 12/31/21



Director of Community and Economic
Development

DISPLAY IN A PROMINENT
LOCATION

VILLAGE OF BENSENVILLE
BUSINESS LICENSE

LICENSE NUMBER
5296

20




Village President

TOY BARN INC
1081 ENTRY DR

21

BENSENVILLE
COMMUNITY & ECONOMIC
DEVELOPMENT

Non-Transferable
Expiration date: 12/31/21



Director of Community and Economic
Development

**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name:: Toy Barn

Phone: 630-422-3157

Business Owner:

Address:

Inspection Date: Andy Samovsky
09/19/2018

Inspector: DON TESSLER

| <u>Checklist #</u> | <u>Violation</u> | <u>Violation comment</u> |
|--------------------|-----------------------------------|---|
| 0001 | IMPROPER DISPLAY OF ADDRESS | Missing a number 8 on the building address. |
| 030I | OBSTRUCTION OF FIRE LANE | No parking in fire lane. |
| 120F | INSTALL GFCI WITH 6' OF WATER | Need GFCI outlets by shop sink. |
| 130 | TRIPLE BASIN REQUIRED | A triple basin required if vehicles are stored in building. |
| 160E | EMERGENCY LIGHTING INOPERABLE | |
| 160G | EM/EXIT LIGHT BURNED OUT | Exit sign need to be on at all times. |
| 160H | NEED EMER. LIGHT BREAKER LOCK | Need a breaker lock on the breaker in the electrical panel controls the Exit sign and emergency lights. |
| 160I | INSTALL 10 POUND ABC EXTINGUISHER | Need two 10lbs ABC fire extinguisher mounted on the wall, by front and rear doors. |
| 160L | FLAME RESISTANT CABINET NEEDED | Need a flame resistant cabinet for any flammable materials, gas cans, etc. |
| 160N | FLAMMABLES SHOULD BE REMOVED | No plastic gas cans in building. |
| 160P | IMPROPER STORAGE IN OFFICE | Can not store motorcycles in office area. |
| 180J | BUSINESS LICENSE - ANNUALLY | need a 2018 Village of Bensenville business license, within 7 days of this inspection. |

Additional Remarks/Comments:

Re-inspection 10-22-18

Reinspection 62828 created on 09/19/2018
by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name:: Toy Barn

Phone: 630-422-3157

Business Owner:

Address:

Inspection Date: Andy Samovsky
09/19/2018

Inspector: DON TESSLER

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name::

Phone: 630-422-3157 Andy

Business Owner: TOY BARN

Address:

Inspection Date:

Inspector: DON TESSLER

10/24/2018

| <u>Checklist #</u> | <u>Violation</u> | <u>Violation comment</u> |
|--------------------|--------------------------------|---|
| 030I | OBSTRUCTION OF FIRE LANE | No parking in fire lane. |
| 120F | INSTALL GFCI WITH 6' OF WATER | Need GFCI outlets by shop sink. |
| 130 | TRIPLE BASIN REQUIRED | A triple basin required if vehicles are stored in building. |
| 160E | EMERGENCY LIGHTING INOPERABLE | Exit sign need to be on at all times. |
| 160G | EM/EXIT LIGHT BURNED OUT | Need a breaker lock on the breaker in the electrical panel controls the Exit sign and emergency lights. |
| 160H | NEED EMER. LIGHT BREAKER LOCK | Need a flame resistant cabinet for any flammable materials, gas cans, etc. |
| 160L | FLAME RESISTANT CABINET NEEDED | No plastic gas cans in building. |
| 160N | FLAMMABLES SHOULD BE REMOVED | |

Additional Remarks/Comments:

Created from inspection 62828 on
10/24/2018 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name::

Phone: 630-422-3157 Andy

Business Owner: TOY BARN

Address:

Inspection Date:

Inspector: DON TESSLER

10/24/2018

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

| | | | |
|--------------------|--------------------------------|---|--------------|
| Address: | 1081 Entry Dr | Unit: | |
| Business name:: | TOY BARN | Phone: | 630-422-3157 |
| Business Owner: | Andy Samovsky | Address: | |
| Inspection Date: | 12/26/2018 | Inspector: | DON TESSLER |
| Checklist # | Violation | Violation comment | |
| 030I | OBSTRUCTION OF FIRE LANE | No parking in fire lane. | |
| 120F | INSTALL GFCI WITH 6' OF WATER | Need GFCI outlets by shop sink. | |
| 130 | TRIPLE BASIN REQUIRED | A triple basin required if vehicles are stored in building. | |
| 160E | EMERGENCY LIGHTING INOPERABLE | Exit sign need to be on at all times. | |
| 160G | EM/EXIT LIGHT BURNED OUT | Need a breaker lock on the breaker in the electrical panel controls the Exit sign and emergency lights. | |
| 160H | NEED EMER. LIGHT BREAKER LOCK | Need a flame resistant cabinet for any flammable materials, gas cans, etc. | |
| 160L | FLAME RESISTANT CABINET NEEDED | No plastic gas cans in building. | |
| 160N | FLAMMABLES SHOULD BE REMOVED | | |

Additional Remarks/Comments:

Created from inspection 63768 on
12/26/2018 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 Entry Dr Unit:
Business name:: TOY BARN Phone: 630-422-3157
Business Owner: Andy Samovsky Address:
Inspection Date: 12/26/2018 Inspector: DON TESSLER

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY DR. Unit:

Business name:: TOY BARN Phone:

Business Owner: Address:

Inspection Date: 01/09/2019 Inspector: DON TESSLER

| Checklist # | Violation | Violation comment |
|-------------|--------------------------------|--|
| 030I | OBSTRUCTION OF FIRE LANE | No parking in fire lane. |
| 130 | TRIPLE BASIN REQUIRED | A triple basin required if vehicles are stored in building. |
| 160L | FLAME RESISTANT CABINET NEEDED | Need a flame resistant cabinet for any flammable materials, gas cans, etc. |
| 160N | FLAMMABLES SHOULD BE REMOVED | No plastic gas cans in building. |

Additional Remarks/Comments:

Created from inspection 64557 on
01/09/2019 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY DR. Unit:

Business name:: TOY BARN Phone:

Business Owner: Address:

Inspection Date: 01/09/2019 Inspector: DON TESSLER

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: TOY BARN INC.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 05/17/2024

Inspector: DON TESSLER

Violation

Violation comment

VILLAGE REGULATIONS

Conducting business outside the scope of your Village of Bensenville business license. A body shop and auto mechanic Work requires a Special use Permit.

ALLOWABLE USES

Need to cease and de-sist all auto body work, spray painting and auto mechanical work until further notice. You do not have a Special use permit to conduct this type of work.

SPRAY BOOTH

Non-compliance spray booth, Need a Village of Bensenville building permit for approved spray booth. Do not use this unapproved paint spraying area.

REMOVE ALL RUBBISH OR GARBAGE

Remove all outside auto parts and garbage in front of the unit.

REMOVE ALL OUTDOOR VEHICLE STORAGE

Can not park unlicensed, inoperable, or junk vehicles in the complex parking lot.

OBSTRUCTION OF FIRE LANE

No parking of vehicles or trailers in the posted Fire lane.

GENERAL HOUSEKEEPING

Need some major cleaning in this unit, Lot of debris on the floor and blocking means of egress and exit doors, very unsafe conditions.

MEANS OF EGRESS BLOCKED

Need to clear all the means of egress though out this building.

CLEAN AND SANITIZE AREA

This unit needs major cleaning and sanitizing.

NEED ACCESS TO ELECTRIC PANEL

Need access to electrical panel and keep min. 36" clear space around panels.

REMOVE ALL EXTENSION CORDS

Remove all extension cords though out this building.

TRIPLE CATCH BASIN CLEAN

Need to clean out the triple catch basin, or a copy of the last service.

EMERGENCY LIGHTING INOPERABLE

Repair/replace all non-working emergency light units.

| | |
|-----------------------------------|--|
| EM/EXIT LIGHT BURNED OUT | Repair/replace all burnt out Exit lights. |
| INSTALL 10 POUND ABC EXTINGUISHER | Need three 10lbs ABC Fire extinguishers with current inspection tag and mounted on the wall. |
| FLAME RESISTANT CABINET NEEDED | Need a metal flame resistant cabinet for all paints and chemicals. |
| FLAMMABLES IMPROPERLY STORED | |
| MSD SHEETS NEED TO BE POSTED | Need a binder with all the MSD sheet on all the chemical used and stored inside this unit. |
| PROPERLY SECURE COMPRESSED GAS | Properly secure all compressed gas tanks with chain to wall or in approved cage. |
| FIRE ALARM NEEDS SERVICING | The fire alarm in this unit might need the detection units cleaned. |
| SUPPRESSION SYSTEM REQUIRED | Spray booth requires a fire suppression unit. |
| KEEP STORAGE 36 IN. FROM HEATING | Keep all storage a min. 36" from all heating equipment. |

Additional Remarks/Comments:

Reinspection # 111532

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 06/17/2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: E-mailed and mailed USPS 05/17/2024 to toybarnsales@gmail.com

DON TESSLER
Inspector

05/17/2024
Date

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: TOY BARN INC.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 06/17/2024

Inspector: DON TESSLER

Violation

VILLAGE REGULATIONS

Violation comment

Conducting business outside the scope of your Village of Bensenville business license. A body shop and auto mechanic Work requires a Special use Permit.

ALLOWABLE USES

Need to cease and de-sist all auto body work, spray painting and auto mechanical work until further notice. You do not have a Special use permit to conduct this type of work.

SPRAY BOOTH

Non-compliance spray booth, Need a Village of Bensenville building permit for approved spray booth. Do not use this paint spraying area.

REMOVE ALL RUBBISH OR GARBAGE

Remove all outside auto parts and garbage.

REMOVE ALL OUTDOOR VEHICLE STORAGE

Can not park unlicensed, inoperable, or junk vehicles in the complex parking lot.

OBSTRUCTION OF FIRE LANE

No parking of vehicles or trailers in the Fire lane.

GENERAL HOUSEKEEPING

Need some major cleaning in this unit, Lot of debris on the floor and blocking means of egress and exit doors.

MEANS OF EGRESS BLOCKED

Need to clear all the means of egress though out this building.

CLEAN AND SANITIZE AREA

This unit needs major cleaning and sanitizing.

NEED ACCESS TO ELECTRIC PANEL

Need access to electrical panel and keep min. 36" clear space around panels.

REMOVE ALL EXTENSION CORDS

Remove all extension cords though out this building.

EMERGENCY LIGHTING INOPERABLE

Repair/replace all non-working emergency light units.

EM/EXIT LIGHT BURNED OUT

Repair/replace all burnt out Exit lights.

FLAMMABLES IMPROPERLY STORED

Need a binder with all the MSD sheet on all the chemical used and stored inside this unit.

MSD SHEETS NEED TO BE POSTED

PROPERLY SECURE COMPRESSED GAS

Properly secure all compressed gas tanks with chain to wall or in approved cage.

FIRE ALARM NEEDS SERVICING

The fire alarm in this unit might need the detection units cleaned.

SUPPRESSION SYSTEM REQUIRED

Spray booth requires a fire suppression unit.

KEEP STORAGE 36 IN. FROM HEATING

Keep all storage a min. 36" from all heating equipment.

Additional Remarks/Comments:

Reinspection # 112552

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 06/17/2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: E-mailed 06/17/2024 to toybarnsales@gmail.com

DON TESSLER

Inspector

06/17/2024

Date

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: TOY BARN, INC.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 09/11/2024

Inspector: DON TESSLER

Violation

VILLAGE REGULATIONS

Violation comment

Conducting business outside the scope of your Village of Bensenville business license. A body shop and auto mechanic Work requires a Special use Permit.

ALLOWABLE USES

Need to cease and de-sist all auto body work, spray painting and auto mechanical work until further notice. You do not have a Special use permit to conduct this type of work.

SPRAY BOOTH

Non-compliance spray booth, Need a Village of Bensenville building permit for approved spray booth. Do not use this paint spraying area.

CLEAN AND SANITIZE AREA

This unit needs major cleaning and sanitizing.

REMOVE ALL EXTENSION CORDS

Remove all extension cords though out this building.

FLAMMABLES IMPROPERLY STORED

MSD SHEETS NEED TO BE POSTED

Need a binder with all the MSD sheet on all the chemical used and stored inside this unit.

FIRE ALARM NEEDS SERVICING

The fire alarm in this unit might need the detection units cleaned.

SUPPRESSION SYSTEM REQUIRED

Spray booth requires a fire suppression unit.

Additional Remarks/Comments:

Reinspection # 115450

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 09/25/2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored

items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: E-mailed 09/11/2024 to toybarnsales@gmail.com

DON TESSLER

Inspector

09/11/2024

Date