



BENSENVILLE
VILLAGE CLERK'S OFFICE

12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

February 13, 2025

President
Frank DeSimone

Mr. Marshall Subach
1035 South York Road
Bensenville, Illinois 60106

Board of Trustees
Rosa Carmona
Ann Franz
Marie T. Frey
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Daniel Schulze

Re: February 7, 2025 FOIA Request

Dear Mr. Subach:

I am pleased to help you with your February 7, 2025 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on February 7, 2025. You requested copies of the items indicated below:

"Copies of all correction notices, inspection reports, administrative hearing orders, citations, tickets issued to Toy Barn Inc. for its business operation at 1081 Entry Drive Bensenville Illinois 60106."

After a search of Village files, the following information was found responsive to your request:

- 1) Village of Bensenville Correction Notice for Inspection No. 62827. (2 pgs.)
- 2) Village of Bensenville Correction Notice for Inspection No. 63768. (2 pgs.)
- 3) Village of Bensenville Correction Notice for Inspection No. 64557. (2 pgs.)
- 4) Village of Bensenville Correction Notice for Inspection No. 64727. (2 pgs.)
- 5) Village of Bensenville Correction Notice for Inspection No. 111530. (2 pgs.)
- 6) Village of Bensenville Correction Notice for Inspection No. 111530. (2 pgs.)
- 7) Village of Bensenville Correction Notice for Inspection No. 112552. (2 pgs.)
- 8) Village of Bensenville Correction Notice for Inspection No. 115450. (2 pgs.)

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville



VILLAGE OF BENSENVILLE FREEDOM OF INFORMATION ACT REQUEST FORM

BENSENVILLE
VILLAGE CLERK'S OFFICE

TO: **COREY WILLIAMSEN**

FROM: Name **Marshall Subach**

*Freedom of Information Officer
Village of Bensenville
12 S. Center Street
Bensenville, IL 60106*

17759

Address **1035 S. York Road
Bensenville, IL 60106**
Phone **(630)860-7800**
E-Mail **mjsubach@7800law.com**

TITLES OR DESCRIPTION OF RECORDS REQUESTED (Please Include Date of Birth and Case Number for Police Records):

Copies of all corection notices, inspection reports, administrative hearing orders, citations, tickets issued to Toy Barn Inc. for its business operations at 1081 Entry Drive Bensenville Illinois 60106


THIS REQUEST IS FOR A COMMERCIAL PURPOSE (*You must state whether your request is for a commercial purpose.* A request is for a "commercial purpose" if all or any part of the information will be used in any form for sale, resale, or solicitation or advertisement for sales or services. Failure to disclose whether a request is for a commercial purpose is a prosecutable violation of FOIA.)

Would like your request delivered via: E-Mail U.S. Mail Pick-Up*

**Pick-Up is available by appointment at Village Hall Monday thru Friday; between 8:00 a.m. - 5:00 p.m.*

I understand that any payment need be received before any documents are copied and/or mailed.

2/7/25


Signature

Date

All FOIA responses are posted on the Village's website. Name and address of the requestor will be made public.

The first fifty (50) pages of the request are free. The fee charge is fifteen (15) cents after the first fifty (50) pages.

Unless otherwise notified, your request for public records will be compiled within five (5) working days.

Unless otherwise notified, any request for commercial purposes will be compiled within twenty-one (21) days working days.

COREY WILLIAMSEN, FREEDOM OF INFORMATION OFFICER

Telephone: (630) 350-3404 Facsimile: (630) 350-3438

E-mail Address: FOIArequest@bensenville.il.us

For Freedom of Information Officer Use Only

2/7/25
Date Request Received

2/18/25
Date Response Due

2/25/25
Date Extended Response Due

\$0
Total Charges

2/13/25
Date Documents Copied or Inspected

Received by Employee: _____



**VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name:: Toy Barn

Phone: 630-422-3157

Business Owner:

Address:

Inspection Date: Andy Samovsky
09/19/2018

Inspector: DON TESSLER

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
0001	IMPROPER DISPLAY OF ADDRESS	Missing a number 8 on the building address.
030I	OBSTRUCTION OF FIRE LANE	No parking in fire lane.
120F	INSTALL GFCI WITH 6' OF WATER	Need GFCI outlets by shop sink.
130	TRIPLE BASIN REQUIRED	A triple basin required if vehicles are stored in building.
160E	EMERGENCY LIGHTING INOPERABLE	Exit sign need to be on at all times.
160G	EM/EXIT LIGHT BURNED OUT	Need a breaker lock on the breaker in the electrical panel controls the Exit sign and emergency lights.
160H	NEED EMER. LIGHT BREAKER LOCK	Need two 10lbs ABC fire extinguisher mounted on the wall, by front and rear doors.
160I	INSTALL 10 POUND ABC EXTINGUISHER	Need a flame resistant cabinet for any flammable materials, gas cans, etc.
160L	FLAME RESISTANT CABINET NEEDED	No plastic gas cans in building.
160N	FLAMMABLES SHOULD BE REMOVED	Can not store motorcycles in office area.
160P	IMPROPER STORAGE IN OFFICE	need a 2018 Village of Bensenville business license, within 7 days of this inspection.
180J	BUSINESS LICENSE - ANNUALLY	

Additional Remarks/Comments:

Re-inspection 10-22-18

Reinspection 62828 created on 09/19/2018
by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within 30 days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name:: Toy Barn

Phone: 630-422-3157

Business Owner:

Address:

Inspection Date: Andy Samovsky
09/19/2018

Inspector: DON TESSLER

Copy of this report received by/mailed to: _____

Inspector: _____

Date: _____



VILLAGE OF BENSENVILLE
INSPECTORIAL SERVICES
 12 South Center
 Bensenville, IL 60106
 630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY Unit:

Business name:: Phone: 630-422-3157 Andy

Business Owner: TOY BARN

Address:

Inspection Date: 10/24/2018 Inspector: DON TESSLER

Checklist #	Violation	Violation comment
030I	OBSTRUCTION OF FIRE LANE	No parking in fire lane.
120F	INSTALL GFCI WITH 6' OF WATER	Need GFCI outlets by shop sink.
130	TRIPLE BASIN REQUIRED	A triple basin required if vehicles are stored in building.
160E	EMERGENCY LIGHTING INOPERABLE	Exit sign need to be on at all times.
160G	EM/EXIT LIGHT BURNED OUT	Need a breaker lock on the breaker in the electrical panel controls the Exit sign and emergency lights.
160H	NEED EMER. LIGHT BREAKER LOCK	Need a flame resistant cabinet for any flammable materials, gas cans, etc.
160L	FLAME RESISTANT CABINET NEEDED	No plastic gas cans in building.
160N	FLAMMABLES SHOULD BE REMOVED	

Additional Remarks/Comments:

Created from inspection 62828 on
 10/24/2018 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY

Unit:

Business name::

Phone: 630-422-3157 Andy

Business Owner: TOY BARN

Address:

Inspection Date:

Inspector: DON TESSLER

10/24/2018

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address:	1081 Entry Dr	Unit:	
Business name::	TOY BARN	Phone:	630-422-3157
Business Owner:	Andy Samovsky	Address:	
Inspection Date:	12/26/2018	Inspector:	DON TESSLER

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
030I	OBSTRUCTION OF FIRE LANE	No parking in fire lane.
120F	INSTALL GFCI WITH 6' OF WATER	Need GFCI outlets by shop sink.
130	TRIPLE BASIN REQUIRED	A triple basin required if vehicles are stored in building.
160E	EMERGENCY LIGHTING INOPERABLE	
160G	EM/EXIT LIGHT BURNED OUT	Exit sign need to be on at all times.
160H	NEED EMER. LIGHT BREAKER LOCK	Need a breaker lock on the breaker in the electrical panel controls the Exit sign and emergency lights.
160L	FLAME RESISTANT CABINET NEEDED	Need a flame resistant cabinet for any flammable materials, gas cans, etc.
160N	FLAMMABLES SHOULD BE REMOVED	No plastic gas cans in building.

Additional Remarks/Comments:

Created from inspection 63768 on
12/26/2018 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 Entry Dr Unit:
Business name:: TOY BARN Phone: 630-422-3157
Business Owner: Andy Samovsky Address:
Inspection Date: 12/26/2018 Inspector: DON TESSLER

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY DR. Unit:

Business name:: TOY BARN Phone:

Business Owner: Address:

Inspection Date: 01/09/2019 Inspector: DON TESSLER

<u>Checklist #</u>	<u>Violation</u>	<u>Violation comment</u>
030I	OBSTRUCTION OF FIRE LANE	No parking in fire lane.
130	TRIPLE BASIN REQUIRED	A triple basin required if vehicles are stored in building.
160L	FLAME RESISTANT CABINET NEEDED	Need a flame resistant cabinet for any flammable materials, gas cans, etc.
160N	FLAMMABLES SHOULD BE REMOVED	No plastic gas cans in building.

Additional Remarks/Comments:

Created from inspection 64557 on
01/09/2019 by 6523dtes

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATIONS WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY.

You are hereby notified to remedy the conditions as stated above within days.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances.

Our inspection can be substantially limited by access available and stored items or furniture.

Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems.

If you have questions about this inspection, please call 630-350-3448.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.



**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**
12 South Center
Bensenville, IL 60106
630-350-3413 fax:630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 ENTRY DR. Unit:

Business name:: TOY BARN Phone:

Business Owner: Address:

Inspection Date: 01/09/2019 Inspector: DON TESSLER

Copy of this report received by/mailed to: _____

Inspector: _____ Date: _____

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: TOY BARN INC.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 05/17/2024

Inspector: DON TESSLER

Violation

Violation comment

VILLAGE REGULATIONS

Conducting business outside the scope of your Village of Bensenville business license. A body shop and auto mechanic Work requires a Special use Permit.

ALLOWABLE USES

Need to cease and de-sist all auto body work, spray painting and auto mechanical work until further notice. You do not have a Special use permit to conduct this type of work.

SPRAY BOOTH

Non-compliance spray booth, Need a Village of Bensenville building permit for approved spray booth. Do not use this unapproved paint spraying area.

REMOVE ALL RUBBISH OR GARBAGE

Remove all outside auto parts and garbage in front of the unit.

REMOVE ALL OUTDOOR VEHICLE STORAGE

Can not park unlicensed, inoperable, or junk vehicles in the complex parking lot.

OBSTRUCTION OF FIRE LANE

No parking of vehicles or trailers in the posted Fire lane.

GENERAL HOUSEKEEPING

Need some major cleaning in this unit, Lot of debris on the floor and blocking means of egress and exit doors, very unsafe conditions.

MEANS OF EGRESS BLOCKED

Need to clear all the means of egress though out this building.

CLEAN AND SANITIZE AREA

This unit needs major cleaning and sanitizing.

NEED ACCESS TO ELECTRIC PANEL

Need access to electrical panel and keep min. 36" clear space around panels.

REMOVE ALL EXTENSION CORDS

Remove all extension cords though out this building.

TRIPLE CATCH BASIN CLEAN

Need to clean out the triple catch basin, or a copy of the last service.

EMERGENCY LIGHTING INOPERABLE

Repair/replace all non-working emergency light units.

EM/EXIT LIGHT BURNED OUT	Repair/replace all burnt out Exit lights.
INSTALL 10 POUND ABC EXTINGUISHER	Need three 10lbs ABC Fire extinguishers with current inspection tag and mounted on the wall.
FLAME RESISTANT CABINET NEEDED	Need a metal flame resistant cabinet for all paints and chemicals.
FLAMMABLES IMPROPERLY STORED	
MSD SHEETS NEED TO BE POSTED	Need a binder with all the MSD sheet on all the chemical used and stored inside this unit.
PROPERLY SECURE COMPRESSED GAS	Properly secure all compressed gas tanks with chain to wall or in approved cage.
FIRE ALARM NEEDS SERVICING	The fire alarm in this unit might need the detection units cleaned.
SUPPRESSION SYSTEM REQUIRED	Spray booth requires a fire suppression unit.
KEEP STORAGE 36 IN. FROM HEATING	Keep all storage a min. 36" from all heating equipment.

Additional Remarks/Comments:

Reinspection # 111532

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 06/17/2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: E-mailed and mailed USPS 05/17/2024 to toybarnsales@gmail.com

DON TESSLER

Inspector

05/17/2024

Date

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: TOY BARN INC.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 06/17/2024

Inspector: DON TESSLER

Violation

VILLAGE REGULATIONS

Violation comment

Conducting business outside the scope of your Village of Bensenville business license. A body shop and auto mechanic Work requires a Special use Permit.

ALLOWABLE USES

Need to cease and de-sist all auto body work, spray painting and auto mechanical work until further notice. You do not have a Special use permit to conduct this type of work.

SPRAY BOOTH

Non-compliance spray booth, Need a Village of Bensenville building permit for approved spray booth. Do not use this paint spraying area.

REMOVE ALL RUBBISH OR GARBAGE

Remove all outside auto parts and garbage.

REMOVE ALL OUTDOOR VEHICLE STORAGE

Can not park unlicensed, inoperable, or junk vehicles in the complex parking lot.

OBSTRUCTION OF FIRE LANE

No parking of vehicles or trailers in the Fire lane.

GENERAL HOUSEKEEPING

Need some major cleaning in this unit, Lot of debris on the floor and blocking means of egress and exit doors.

MEANS OF EGRESS BLOCKED

Need to clear all the means of egress though out this building.

CLEAN AND SANITIZE AREA

This unit needs major cleaning and sanitizing.

NEED ACCESS TO ELECTRIC PANEL

Need access to electrical panel and keep min. 36" clear space around panels.

REMOVE ALL EXTENSION CORDS

Remove all extension cords though out this building.

EMERGENCY LIGHTING INOPERABLE

Repair/replace all non-working emergency light units.

EM/EXIT LIGHT BURNED OUT

Repair/replace all burnt out Exit lights.

FLAMMABLES IMPROPERLY STORED

Need a binder with all the MSD sheet on all the chemical used and stored inside this unit.

MSD SHEETS NEED TO BE POSTED

PROPERLY SECURE COMPRESSED GAS

Properly secure all compressed gas tanks with chain to wall or in approved cage.

FIRE ALARM NEEDS SERVICING

The fire alarm in this unit might need the detection units cleaned.

SUPPRESSION SYSTEM REQUIRED

Spray booth requires a fire suppression unit.

KEEP STORAGE 36 IN. FROM HEATING

Keep all storage a min. 36" from all heating equipment.

Additional Remarks/Comments:

Reinspection # 112552

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 06/17/2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: E-mailed 06/17/2024 to toybarnsales@gmail.com

DON TESSLER

Inspector

06/17/2024

Date

**VILLAGE OF BENSENVILLE
INSPECTIONAL SERVICES**

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: TOY BARN, INC.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 09/11/2024

Inspector: DON TESSLER

Violation

VILLAGE REGULATIONS

Violation comment

Conducting business outside the scope of your Village of Bensenville business license. A body shop and auto mechanic Work requires a Special use Permit.

ALLOWABLE USES

Need to cease and de-sist all auto body work, spray painting and auto mechanical work until further notice. You do not have a Special use permit to conduct this type of work.

SPRAY BOOTH

Non-compliance spray booth, Need a Village of Bensenville building permit for approved spray booth. Do not use this paint spraying area.

CLEAN AND SANITIZE AREA

This unit needs major cleaning and sanitizing.

REMOVE ALL EXTENSION CORDS

Remove all extension cords though out this building.

FLAMMABLES IMPROPERLY STORED

MSD SHEETS NEED TO BE POSTED

Need a binder with all the MSD sheet on all the chemical used and stored inside this unit.

FIRE ALARM NEEDS SERVICING

The fire alarm in this unit might need the detection units cleaned.

SUPPRESSION SYSTEM REQUIRED

Spray booth requires a fire suppression unit.

Additional Remarks/Comments:

Reinspection # 115450

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 09/25/2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored

items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: E-mailed 09/11/2024 to toybarnsales@gmail.com

DON TESSLER

Inspector

09/11/2024

Date

VILLAGE OF BENSENVILLE INSPECTIONAL SERVICES

12 South Center
Bensenville, IL 60106
630-350-3413 fax: 630-350-3449

Type of Inspection: NON-RESIDENTIAL INSPECTION

CORRECTION NOTICE

Address: 1081 SOUTH ENTRY DRIVE

Unit:

Business Name: Toy Barn Inc.

Phone: 847-873-9649

Business Owner: Andy Samovsky

Address: 1081 ENTRY DRIVE

Inspection Date: 01/30/2025

Inspector:

Violation

CLEAN AND SANITIZE AREA

Violation comment

This unit is very dusty, would like to see it cleaned up.
Excess dust will effect the heating and ventilation system.

REMOVE ALL EXTENSION CORDS

Remove all extension cords throughout this building.
Extension cord for hoist in the ceiling.

HEATING

The bottom pan for the hanging furnace is open, this needs to be closed.

BATHROOM EXHAUST FAN(S)

Bathroom without exterior windows require an exhaust fan to the outside of the building.

FLAMMABLES IMPROPERLY STORED

All flammable liquids need to be placed in an approved Flame resistant cabinet. ie: paint cans, solvents, grease, oil.

MSD SHEETS NEED TO BE POSTED

Need a binder with all the MSD sheet for all the chemicals used and stored inside this unit.

FIRE ALARM SYSTEM - ANNUAL CERTIFICATION Need annual fire alarm test and inspection paper work.

SPRAY BOOTH

Spray booths will require a separate permit along with a fire suppression system. If you intend to spray paint vehicles and spare parts a spray booth will be required.

Additional Remarks/Comments: re-inspection ID # 120373

THOSE ITEMS LISTED ABOVE ARE VIOLATIONS OF BENSENVILLE'S ADOPTED VILLAGE CODE AND/OR PROPERTY MAINTENANCE CODE. THIS IS YOUR WRITTEN "CORRECTION NOTICE". FAILURE TO CORRECT THE ABOVE LISTED VIOLATION WITHIN THE PRESCRIBED TIME CAN RESULT IN A FINE OF UP TO \$750 PER VIOLATION, PER DAY ASSIGNED BY A JUDICATOR.

You are hereby notified to remedy the conditions as stated above by 03-03-2024.

Neither this inspection nor any Certificate of Occupancy issued by the Village of Bensenville shall be considered a complete list of Code or Municipal Ordinances. Our inspection can be substantially limited by access available and stored items or furniture. Some occupancies may require inspections to be completed on individual systems such as heating appliances, roofing, structure or fire protection systems. If you have questions about this inspection, please call 630-350-3413.

DISCLAIMER: The Village of Bensenville does not warrant the condition of any property inspected and disclaims all liability for any claims arising out of the property or condition thereof.

Copy of this report received by/mailed to: _____

Inspector

01/30/2025

Date