



NOTE:

1. NOTIFY P/W UTILITY DIVISION 48 HOURS PRIOR TO START OF CONSTRUCTION AT (630) 350-3435.
2. COORDINATE WATER SHUTDOWN WITH THE PUBLIC WORKS DEPARTMENT, EXCAVATE AREA AND DISCONNECT HYDRANT LEAD, PLATE TEE, BLOCK AND RESTRAIN.
3. RETURN HYDRANT, AUXILIARY VALVE AND BOX TO PUBLIC WORKS DEPARTMENT.
4. BACKFILL AND COMPACTION PER THE VILLAGE OF BENSENVILLE STANDARD.
5. EXISTING TEE MUST BE CUT OUT AND REPLACED WITH A SOLID SECTION OF PIPE.
6. ALL FASTENERS HARDWARE (i.e., NUTS, BOLTS, AND WASHERS) ASSOCIATED WITH THE MECHANICAL JOINT MUST BE STAINLESS STEEL.