


**NOTE:**

1. THE CASING SPACER SHALL BE THE CENTERED AND RESTRAINED TYPE.
2. THE SPACER BANDS SHALL BE STAINLESS STEEL.
3. ALL FASTENER HARDWARE (i.e. NUTS, BOLTS, AND WASHERS) ASSOCIATED WITH THE CASING SPACERS SHALL BE STAINLESS STEEL.
4. THE SPACERS SHALL BE STAINLESS STEEL OR VILLAGE APPROVED EQUAL.



**SECTION A - A**