



NOTES

1. STAINLESS STEEL SADDLE SMITH-BLAIR TYPE 238 TAPPED FULL CIRCLE REPAIR CLAMP (304 STAINLESS STEEL BOLTS & 12-1/2" BAND WIDTH) OR APPROVED EQUAL.
2. FOR PVC WATERMAIN - USE DOUBLE STUD STAINLESS STEEL SADDLE AND BOLTS(SMITH BLAIR 372).
3. TEFILON PASTE OR TAPE SHALL NOT BE ALLOWED.
4. WATER SERVICE AND FIRE SUPPRESSION SYSTEM SHALL BE MADE AND INSTALLED BY A LICENSED PLUMBER, IN ACCORDANCE WITH THE ILLINOIS STATE PLUMBING CODE.
5. USE FLARED FITTINGS FOR ALL CONNECTIONS.
6. ROD & RING GUIDE TO BE USED ON 3/4" AND 1" SERVICES ONLY.